

**STATE OF ALASKA ITB #2024-2000-0254  
AMENDMENT #3**

*RETURN THIS AMENDMENT TO THE ISSUING OFFICE AT:*



Department of Corrections  
Division of Administrative Services  
550 W. 7<sup>th</sup> Ave., Suite 1800  
Anchorage, AK 99501

**THIS IS NOT AN ORDER**

**DATE AMENDMENT ISSUED: 03/11/2024**

**ITB TITLE: BOILERS AND COMPONENTS**

**ITB OPENING DATE AND TIME: March 15, 2024, 2PM AKST.**

Please see the following Q & A's to this ITB:

1. Is the fuel system on-site a standard natural gas system or a "synthetic" natural gas being delivered to the boilers?

**Response:** Standard Natural Gas


2. What is the heat transfer fluid in this boiler system?

**Response:** Polypropylene Glycol

3. Are the boiler exhaust flues roof venting or side wall venting?

**Response:** Roof

**In order for your bid to be considered responsive, this amendment, in addition to your original bid, must be received by the Procurement Officer prior to the time set for the bid opening.**

  
\_\_\_\_\_  
Allan Oyao  
Procurement Officer  
PHONE: (907) 269-5910  
EMAIL: [allan.oyao@alaska.gov](mailto:allan.oyao@alaska.gov)

\_\_\_\_\_  
NAME OF COMPANY

\_\_\_\_\_  
SIGNATURE

\_\_\_\_\_  
DATE

**FOR STATE USE ONLY - THIS AMENDMENT COVERS PR# N/A**