

STATE OF ALASKA ITB #2024-2000-0254

AMENDMENT #4

RETURN THIS AMENDMENT TO THE ISSUING OFFICE AT:



Department of Corrections
Division of Administrative Services
550 W. 7th Ave., Suite 1800
Anchorage, AK 99501

THIS IS NOT AN ORDER

DATE AMENDMENT ISSUED: 03/13/2024

ITB TITLE: BOILERS AND COMPONENTS

ITB OPENING DATE AND TIME: March 15, 2024, 2PM AKST.

Please see the following Q & A's to this ITB:

1. For the condensing boiler exhaust vent flue piping, is stainless steel flue piping an acceptable alternative to polypropylene?

Response: No.

In order for your bid to be considered responsive, this amendment, in addition to your original bid, must be received by the Procurement Officer prior to the time set for the bid opening.



Allan Oyao
Procurement Officer
PHONE: (907) 269-5910
EMAIL: allan.oyao@alaska.gov

NAME OF COMPANY

SIGNATURE

DATE

FOR STATE USE ONLY - THIS AMENDMENT COVERS PR# N/A