



Issue Date: March 14, 2024

ATTN: Vendors

**RE: Project Name:** ITB Hangar Door Inspections and General Maintenance  
**Project Number:** STWIDE23047  
**Project Location(s):** Anchorage, AK: Bethel, AK: JBER, AK: Juneau, AK: Kotzebue, AK: Nome, AK

**Addendum # Four (4)**

This addendum forms a part of the contract documents and modifies the original drawings and/or specifications for the subject work. In case of conflicts between this addendum and previously issued documents, this addendum shall take precedence.

**Questions and Answers:**

1. How old is building 47430 (hangar 1), located on Bryant Army Airfield, JBER, Alaska?
  - A. The facility build date was June 8, 1996.
2. Does the west side hangar door of hangar 1, building 47430, stick when opening or closing?
  - A. This hangar door when opening has a tendency to stick and does not open fully a minimum of 5-times per year on average.

Please contact me if you have any questions.

Sincerely

Gavin M. Fairbanks

Building Management Specialist

(907) 428-7187

End of Addendum