

1. We don't see the type of seed that you would like in the specs. Please verify what type of seed mix you would like incorporated in to your project. Typically the DOT will specify the seed mix in the special specifications for each job. I've included the spec sheet for the last DOT highway job in Kodiak, let us know if this will suffice for your application. **Yes, the proposed seed mix will suffice.**
2. The DOT likes a little lighter application rate for their seed, but we'd recommend more with our growing season so short. Let us know what you would like. **AAC concurs and a thicker application to ensure growth during the growing season is acceptable.**
3. Would you like a standard BFM mulch included in your mix, or a modified BFM with tackifier? - **AAC would like to know your recommendation and reasoning behind recommendation.**
4. With the completion date of 10/31/24, you will not get any growth until Spring of 2025. The seed will essentially sit dormant throughout the winter. We would recommend having a completion date of no later than 8/31/24, unless a dormant hydroseed is satisfactory to you. **AAC concurs with your recommendation.**
5. Is watering maintenance required for the seed until 75% growth is apparent? **ACC would like a separate line item for pricing for watering maintenance to this area as an extra that will be decide upon prior to contract issuance.**
6. What date will the areas be available to begin the application the of the hydroseed? – The areas can be made available on – **The areas is available with a one week notice, there are no anticipated restrictions on access to the site.**
7. Who is responsible for protection and of the hydroseeded areas? We are concerned about foot, vehicular, and animal traffic damage. – **ACC would like a separate line item for pricing to install temp. protection to this area as an extra that will be decide upon prior to contract issuance.**