



STATE OF ALASKA
DEPARTMENT OF MILITARY AND VETERANS AFFAIRS

SMALL PROCUREMENT DOCUMENTS
(CONSTRUCTION RELATED)

[per AS 36.30.320(a)]

ADDENDUM NUMBER: 3

Project Title.: <u>176th CES ANG Humidifiers Repairs</u>	Contracting Agency: Department of Military and Veterans Affairs Division of Administrative Services 49000 Army Guard Rd. JBER, AK 99505
Project Number: <u>FXSB241267</u>	
Location: <u>17455 Airlifter Drive</u> <u>Joint Base Elmendorf-Richardson, Alaska 99506</u>	
Procurement Officer: <u>Brandy L. Halverson</u> Phone: 907-428-7222 Email: MvaDasProcurement@alaska.gov	
The IFQ Package is hereby clarified or changed as follows: 1. Q: Does it have to be the same manufacturer for the replacement? A: No, we would like the replacement to be the equivalent of what we have installed. 2. Q: Does the condensate pump need to be replaced as well? A: Yes. All other terms and conditions remain the same. END OF ADDENDUM Your participation in this solicitation is appreciated.	