

**INVITATION TO BID
25-N1063C
Fairbanks Regional Public Health Center – Roof Replacement**

Issued: September 17, 2024

ADDENDUM NO. 2

Information in this addendum takes precedence over original information. All other provisions of the document remain unchanged.

Note to Bidders: Bidders are required to acknowledge this addendum on the bid form.

This addendum consists of:

1. Addendum No. 2 document consisting of 1 page
2. Contractor Questions
3. Attachments:
 - FPHC Architectural As-Builts.pdf
 - FPHC SM&E As-Builts.pdf
4. Bid Deadline remains **September 24, 2024 @ 2:00 PM**

Contractor Questions

Question from Ace Roofing

Question 1. Is Duro-Last PVC 60 mil membrane an approved product for substitution?

Response: Duro-Last PVC 60 mil is not an acceptable approved equal roofing product.

See the Project Notes on Sheet RR-1 Section D General, note #3: *EPDM Roofing material shall be 60 mil unreinforced EPDM.*

END OF ADDENDUM 2

Issued: 9/17/24