

PRI	sort	BLDG	Asset	Description	location	model	BACNET	AI	DI	AO	DO	explanation	Status Notes
		FIRST ROW	FIRST ROW	FIRST ROW		FIRST ROW						FIRST ROW	
1	RMT	60820	CC820-RMT	Room Temps					30			T-Stats for Zone Valves	Need to Verify count
1	STROBE	60820	CC820-STR	ALARM STROBE	outside						1	Winter Watchman Strobe Light	
2	ACD	60820	CC820-ACD-1	AIR CONDITIONER RTU	Annex	Trane	maybe	1	2			Alarm,Status, SAT, plus BacNet points	
1	AHU	60820	CC820-AHU-1	AIR HANDLER UNIT	outside	MFG-DAIKIN, MDL - I	yes	1	2	1		SS, Run Status, SAS, SAT, ALARM, plus BacNet points	
1	AHU	60820	CC820-AHU-2	AIR HANDLER UNIT	outside	MFG-DAIKIN, MDL - I	yes	1	2	1		SS, Run Status, SAS, SAT, ALARM, plus BacNet points	
1	AHU	60820	CC820-AHU-3	AIR HANDLER UNIT	outside	MFG-DAIKIN, MDL - I	yes	1	2	1		SS, Run Status, SAS, SAT, ALARM, plus BacNet points	
1	AHU	60820	CC820-AHU-4	AIR HANDLER UNIT	outside	MFG-DAIKIN, MDL - I	yes	1	2	1		SS, Run Status, SAS, SAT, ALARM, plus BacNet points	
3	BFEP	60820	CC820-BFEP-1	BOILER FEED PUMP	Barracks	AXIOM MF-200					1	Glycol Level alarm	
2	CP	60820	CC820-CP-1	CIRCULATING PUMP	Annex	magna40-120		1	1			ss status, proof (Monitoring only)	
2	CP	60820	CC820-CP-2	CIRCULATING PUMP	Annex	ups26-99fc		1	1			ss status, proof (Monitoring only)	
2	CP	60820	CC820-CP-3	CIRCULATING PUMP	Barracks	up26-1200		1	1			ss status, proof (Monitoring only)	
2	CP	60820	CC820-CP-4	CIRCULATING PUMP	Barracks	up26-1200		1	1			ss status, proof (Monitoring only)	
2	CP	60820	CC820-CP-5	CIRCULATING PUMP	Barracks	magna 3		1	1			ss status, proof (Monitoring only)	
2	CP	60820	CC820-CP-6	CIRCULATING PUMP	Barracks	magna 3		1	1			ss status, proof (Monitoring only)	
2	CP	60820	CC820-CP-7	CIRCULATING PUMP	Barracks	up15-18		1	1			ss status, proof (Monitoring only)	
9	CUH	60820	CC820-CUH-1	CABINET UNIT HEATER				1	1			ss, proof (t-stat cmd, temp out)	
9	CUH	60820	CC820-CUH-10	CABINET UNIT HEATER				1	1			ss, proof (t-stat cmd, temp out)	
9	CUH	60820	CC820-CUH-2	CABINET UNIT HEATER				1	1			ss, proof (t-stat cmd, temp out)	
9	CUH	60820	CC820-CUH-3	CABINET UNIT HEATER				1	1			ss, proof (t-stat cmd, temp out)	
9	CUH	60820	CC820-CUH-4	CABINET UNIT HEATER				1	1			ss, proof (t-stat cmd, temp out)	
9	CUH	60820	CC820-CUH-5	CABINET UNIT HEATER				1	1			ss, proof (t-stat cmd, temp out)	
9	CUH	60820	CC820-CUH-6	CABINET UNIT HEATER				1	1			ss, proof (t-stat cmd, temp out)	
9	CUH	60820	CC820-CUH-7	CABINET UNIT HEATER				1	1			ss, proof (t-stat cmd, temp out)	
9	CUH	60820	CC820-CUH-8	CABINET UNIT HEATER				1	1			ss, proof (t-stat cmd, temp out)	
9	CUH	60820	CC820-CUH-9	CABINET UNIT HEATER				1	1			ss, proof (t-stat cmd, temp out)	
8	EF	60820	CC820-EF-1	EXHAUST FAN							2	ss status, proof (Monitoring only)	
8	EF	60820	CC820-EF-10	EXHAUST FAN							2	ss status, proof (Monitoring only)	
8	EF	60820	CC820-EF-11	EXHAUST FAN							2	ss status, proof (Monitoring only)	
8	EF	60820	CC820-EF-2	EXHAUST FAN							2	ss status, proof (Monitoring only)	
8	EF	60820	CC820-EF-3	EXHAUST FAN							2	ss status, proof (Monitoring only)	
8	EF	60820	CC820-EF-4	EXHAUST FAN							2	ss status, proof (Monitoring only)	
8	EF	60820	CC820-EF-5	EXHAUST FAN							2	ss status, proof (Monitoring only)	
8	EF	60820	CC820-EF-6	EXHAUST FAN							2	ss status, proof (Monitoring only)	
8	EF	60820	CC820-EF-7	EXHAUST FAN							2	ss status, proof (Monitoring only)	
8	EF	60820	CC820-EF-8	EXHAUST FAN							2	ss status, proof (Monitoring only)	
8	EF	60820	CC820-EF-9	EXHAUST FAN							2	ss status, proof (Monitoring only)	
	ZONE	60820		Hydronic Heating System	Annex								Need count of T-stats, Zone Valves
1	BLR	60820	CC820-GB-1	BOILER, GAS	Annex	wbn081		3	2		1	Supply temp, Return temp, Pressure, Run proof, Alarm, SS	
	ZONE	60820		Hydronic Heating System	Barracks								Need count of T-stats, Zone Valves
1	BLR	60820	CC820-GB-2	BOILER, GAS	Barracks	KBN286		3	2		1	Supply temp, Return temp, Pressure, Run proof, Alarm, SS	
1	BLR	60820	CC820-GB-3	BOILER, GAS	Barracks	KBN286		3	2		1	Supply temp, Return temp, Pressure, Run proof, Alarm, SS	
2	HRV1	60820	CC820-HRV-1	HEAT RECOVERY VENTILATOR 1 coil	Annex	american aldes500DDD		1	3	1	1	SS, proof, discharge temp, heat coil actuator, Low Temp sw, ALARM	
3	WH-HE	60820	CC820-WH-3	HOT WATER HEATER, GAS	Barracks	rheem GHE100ES-400A		1	1			Temp, Dry contact Alarm input (have not verified availability)	
3	WH-HE	60820	CC820-WH-4	HOT WATER HEATER, GAS	Barracks	rheem GHE100ES-400A		1	1			Temp, Dry contact Alarm input (have not verified availability)	
3	WH-HE	60820	CC820-WH-5	HOT WATER HEATER, GAS	Barracks	rheem GHE100ES-400A		1	1			Temp, Dry contact Alarm input (have not verified availability)	
2	COMP	60820	CC820-AC-1	AIR COMPRESSOR, dry Fire Sprinkler	Annex			1	1			PSI, run status	
4	FAS	60820	CC820-FAS-2	FIRE ALARM SYSTEM							3	Trouble, Supervisory, Alarm (have not verified availability)	
4	FSS	60820	CC820-FSS-1	FIRE SUPPRESSION SYSTEM, sprinkler							1	Trouble (have not verified availability)	
9	UH	60820	CC820-UH-1	UNIT HEATER, GAS				1	1			ss, proof (t-stat cmd, temp out)	
9	UH	60820	CC820-UH-2	UNIT HEATER, GAS				1	1			ss, proof (t-stat cmd, temp out)	
												ss, proof (t-stat cmd, temp out)	
1	AHU	60606	CC606-AHU-1	AIR HANDLER UNIT	outside	Trane	maybe	1	2	1		SS, Run Status, SAS, SAT, ALARM, plus BacNet points	
2	CP	60606	CC606-CP-1	CIRCULATING PUMP				1	1			ss status, proof (Monitoring only)	
3	FAF	60606	CC606-FAF-1	FORCED AIR FURNACE	Old section			1	1			T-stat status, Duct temp	
1	RMT	60606	CC606-RMT	Room Temps					10			need count of room temps	Need to Verify count
1	STROBE	60606	CC606-STR	ALARM STROBE	outside						1	Winter Watchman Strobe Light	

2	COMP	60606	CC606-AC-1	AIR COMPRESSOR, dry Fire Sprinkler				1	1		PSI, run status	
8	EF	60606	CC606-EF-1	EXHAUST FAN					2		ss status, proof (Monitoring only)	
8	EF	60606	CC606-EF-2	EXHAUST FAN					2		ss status, proof (Monitoring only)	
8	EF	60606	CC606-EF-3	EXHAUST FAN					2		ss status, proof (Monitoring only)	
8	EF	60606	CC606-EF-4	EXHAUST FAN					2		ss status, proof (Monitoring only)	
4	FAS	60606	CC606-FAS-1	FIRE ALARM SYSTEM					3		Trouble, Supervisory, Alarm (have not verified availability)	
4	FSS	60606	CC606-FSS-1	FIRE SUPPRESSION SYSTEM, sprinkler		fire pump			1		Trouble (have not verified availability)	
5	WH	60606	CC606-WH-1	HOT WATER HEATER, GAS				1			Temp	
5	WH	60606	CC606-WH-2	HOT WATER HEATER, ELECTRIC				1			Temp	
3	WH-HE	60606	CC606-WH-3	HOT WATER HEATER, GAS	Barracks	rheem GHE100ES-400A		1	1		Temp, Dry contact Alarm input (have not verified availability)	
2	COMP	57226	CC226-AC-1	AIR COMPRESSOR, dry Fire Sprinkler				1	1		PSI, run status	
1	AHU	57226	CC226-AHU-1	AIR HANDLER UNIT	outside	Trane	maybe	1	2	1	SS, Run Status, SAS, SAT, ALARM, plus BacNet points	
2	BFEP	57226	CC226-BFEP-1	BOILER FEED PUMP		AXIOM MF-200		1	1		Glycol Level alarm	
1	RMT	57226	CC226-BLDG	Room Temps				4			T-Stats for Zone Valves	Need to Verify T-Stat count
2	CP	57226	CC226-CP-1	CIRCULATING PUMP				1	1		ss status, proof (Monitoring only)	
2	CP	57226	CC226-CP-2	CIRCULATING PUMP				1	1		ss status, proof (Monitoring only)	
	ZONE	57226		Hydronic Heating System								Need count of T-stats, Zone Valves
1	BLR	57226	CC226-GB-1	BOILER, GAS				3	2		1 Supply temp, Return temp, Pressure, Run proof, Alarm, SS	
1	STROBE	57226	CC226-STR	ALARM STROBE	outside						1 Winter Watchman Strobe Light	
8	EF	57226	CC226-EF-1	EXHAUST FAN					2		ss status, proof (Monitoring only)	
8	EF	57226	CC226-EF-2	EXHAUST FAN					2		ss status, proof (Monitoring only)	
8	EF	57226	CC226-EF-4	EXHAUST FAN					2		ss status, proof (Monitoring only)	
8	EF	57226	CC226-EF-5	EXHAUST FAN					2		ss status, proof (Monitoring only)	
4	FAS	57226	CC226-FAS-1	FIRE ALARM SYSTEM					3		Trouble, Supervisory, Alarm (have not verified availability)	
4	FSS	57226	CC226-FSS-1	FIRE SUPPRESSION SYSTEM, sprinkler					1		Trouble (have not verified availability)	
9	UH	57226	CC226-UH-1	UNIT HEATER, GAS				1	1		ss, proof (t-stat cmd, temp out)	
5	WH	57226	CC226-WH-2	HOT WATER HEATER, GAS				1			Temp	
3	WH-HE	57226	CC226-WH-3	HOT WATER HEATER, GAS	Barracks	rheem GHE100ES-400A		1	1		Temp, Dry contact Alarm input (have not verified availability)	
1	RMT	57024	CC024-RMT	Room Temps				5			T-Stats for Zone Valves (not VAV)	Need to Verify T-Stat count
2	CP	57024	CC024-CP-1	CIRCULATING PUMP	BLR rm	Grundfos Magna 3		1	1	1	ss status, proof (Monitoring and control Lead Lag))	
2	CP	57024	CC024-CP-2	CIRCULATING PUMP	BLR rm	Grundfos Magna 3		1	1	1	ss status, proof (Monitoring and control Lead Lag))	
2	CP	57024	CC024-CP-3	CIRCULATING PUMP	BLR rm	Grundfos UP2664F		1	1		ss status, proof (Monitoring only)	
2	CP	57024	CC024-CP-4	CIRCULATING PUMP	BLR rm	Grundfos Alpha 15-55F		1	1		ss status, proof (Monitoring only)	
2	CP	57024	CC024-CP-5	CIRCULATING PUMP	BLR rm	Grundfos UPS2699FC		1	1		ss status, proof (Monitoring only)	
2	CP	57024	CC024-CP-6	CIRCULATING PUMP, DOMWAT	OldBLRrm	Grundfos UPS 15 58		1	1		ss status, proof (Monitoring only)	
2	CP	57024	CC024-CP-7	CIRCULATING PUMP, DOMWAT	OldBLRrm	Grundfos UPS 15 42F		1	1		ss status, proof (Monitoring only)	
2	HRV1	57024	CC024-HRV-1	HEAT RECOVERY VENTILATOR 1 coil	BLR rm			1	3	1	1 SS, proof, discharge temp, heat coil actuator, Low Temp sw, ALARM	
1	RTU	57024	CC024-RTU-1	ROOF TOP UNIT (HVAC)	roof	Daiken-DPS007AHM	yes	1	2	1	SS, Run Status, SAS, SAT, ALARM, plus BacNet points	
1	ACD	57024	CC024-ACD-2	AIR CONDITIONER	Server rm	Liebert-DME037E-PC	maybe	1	1		Alarm, SAT	
	ZONE	57024		Hydronic Heating System								Need count of T-stats, Zone Valves
1	RMT	57024	CC024-RMT	Room Temps				3			Room Temp Sensor only	Need to Verify T-Stat count
1	RMT	57024	CC024-RMT	Room Temps				7			T-Stats for VAV w/Reheat coils	
1	BLR	57024	CC024-GB-1	BOILER, GAS	BLR rm	Lochinvar		3	2		1 Supply temp, Return temp, Pressure, Run proof, Alarm, SS	
1	VAV	57024	CC024-VAV	7 VAV boxes w/reheat				3		2	RMT, RMS, VLV%,DMP%, CFM,DAT all points for each of 7 VAV boxes	
1	TB-BB	57024	CC024-BB	1 Term box w/bb				3		1	RMT, RMS, VLV%	
1	STROBE	57024	CC024-STR	ALARM STROBE	outside						1 Winter Watchman Strobe Light	
9	CUH	57024	CC024-CUH-1	CABINET UNIT HEATER				1	1		ss, proof (t-stat cmd, temp out)	
8	EF	57024	CC024-EF-1	EXHAUST FAN					2		ss status, proof (Monitoring only)	
8	EF	57024	CC024-EF-10	EXHAUST FAN					2		ss status, proof (Monitoring only)	
8	EF	57024	CC024-EF-2	EXHAUST FAN					2		ss status, proof (Monitoring only)	
8	EF	57024	CC024-EF-3	EXHAUST FAN					2		ss status, proof (Monitoring only)	
8	EF	57024	CC024-EF-4	EXHAUST FAN					2		ss status, proof (Monitoring only)	
8	EF	57024	CC024-EF-5	EXHAUST FAN					2		ss status, proof (Monitoring only)	
8	EF	57024	CC024-EF-6	EXHAUST FAN					2		ss status, proof (Monitoring only)	
8	EF	57024	CC024-EF-7	EXHAUST FAN					2		ss status, proof (Monitoring only)	
8	EF	57024	CC024-EF-8	EXHAUST FAN					2		ss status, proof (Monitoring only)	
8	EF	57024	CC024-EF-9	EXHAUST FAN					2		ss status, proof (Monitoring only)	

4	FAS	57024	CC024-FAS-1	FIRE ALARM SYSTEM					3		Trouble, Supervisory, Alarm (have not verified availability)	
5	WH-I	57024	CC024-WH-1	HOT WATER HEATER, INDIRECT		Lochinvar Squire			1		Temp	
1	GEN	57024	CC024-EMGEN-1	EMERGENCY GENERATOR		don't know if it exist: maybe		1	4		ss status, proof, tank level, leak sensor, alarm, oil pressure, water temp	
1	RMT	57040	CC040-RMT	Room Temps					3		T-Stats for Zone Valves	Need to Verify T-Stat count
1	STROBE	57040	CC040-STR	ALARM STROBE	outside					1	Winter Watchman Strobe Light	
2	CP	57040	CC040-CP-1	CIRCULATING PUMP				1	1		ss status, proof (Monitoring only)	
	ZONE	57040		Hydronic Heating System								Need count of T-stats, Zone Valves
1	BLR	57040	CC040-GB-1	BOILER, GAS				3	2	1	Supply temp, Return temp, Pressure, Run proof, Alarm, SS	
8	EF	57040	CC040-EF-1	EXHAUST FAN					2		ss status, proof (Monitoring only)	
8	EF	57040	CC040-EF-2	EXHAUST FAN					2		ss status, proof (Monitoring only)	
8	EF	57040	CC040-EF-3	EXHAUST FAN					2		ss status, proof (Monitoring only)	
8	EF	57040	CC040-EF-4	EXHAUST FAN					2		ss status, proof (Monitoring only)	
4	FAS	57040	CC040-FAS-1	FIRE ALARM SYSTEM					3		Trouble, Supervisory, Alarm (have not verified availability)	
5	WH	57040	CC040-WH-1	HOT WATER HEATER, GAS					1		Temp	
1	AHU	57114	CC114-AHU-1	AIR HANDLER UNIT	outside	Trane	maybe	1	2	1	SS, Run Status, SAS, SAT, ALARM, plus BacNet points	
1	RMT	57114	CC114-RMT	Room Temps					3		room temp sensors	Need to Verify T-Stat count
1	STROBE	57114	CC114-STR	ALARM STROBE	outside					1	Winter Watchman Strobe Light	
8	EF	57114	CC114-EF-1	EXHAUST FAN					2		ss status, proof (Monitoring only)	
8	EF	57114	CC114-EF-2	EXHAUST FAN					2		ss status, proof (Monitoring only)	
8	EF	57114	CC114-EF-3	EXHAUST FAN					2		ss status, proof (Monitoring only)	
4	FAS	57114	CC114-FAS-1	FIRE ALARM SYSTEM					3		Trouble, Supervisory, Alarm (have not verified availability)	
5	WH	57114	CC114-WH-1	HOT WATER HEATER, GAS					1		Temp	
1	RMT	57116	CC116-RMT	Room Temps					3		room temp sensors	Need to Verify T-Stat count
1	STROBE	57116	CC116-STR	ALARM STROBE	outside					1	Winter Watchman Strobe Light	
3	FAF	57116	CC116-FAF-1	FORCED AIR FURNACE				1	1		T-stat status, Duct temp	
3	FAF	57116	CC116-FAF-2	FORCED AIR FURNACE				1	1		T-stat status, Duct temp	
8	EF	57116	CC116-EF-1	EXHAUST FAN					2		ss status, proof (Monitoring only)	
8	EF	57116	CC116-EF-2	EXHAUST FAN					2		ss status, proof (Monitoring only)	
4	FAS	57116	CC116-FAS-1	FIRE ALARM SYSTEM					3		Trouble, Supervisory, Alarm (have not verified availability)	
9	UH	57116	CC116-UH-1	UNIT HEATER, GAS				1	1		ss, proof (t-stat cmd, temp out)	
9	UH	57116	CC116-UH-2	UNIT HEATER, GAS				1	1		ss, proof (t-stat cmd, temp out)	
9	UH	57116	CC116-UH-3	UNIT HEATER, GAS				1	1		ss, proof (t-stat cmd, temp out)	
9	UH	57116	CC116-UH-4	UNIT HEATER, GAS				1	1		ss, proof (t-stat cmd, temp out)	
9	UH	57116	CC116-UH-5	UNIT HEATER, ELECTRIC				1	1		ss, proof (t-stat cmd, AMPS out)	
5	WH	57116	CC116-WH-1	HOT WATER HEATER, ELECTRIC					1		Temp	
5	WH	57116	CC116-WH-2	HOT WATER HEATER, ELECTRIC					1		Temp	
1	RMT	60810	CC810-RMT	Room Temps					3		room temp sensors	Need to Verify T-Stat count
1	STROBE	60810	CC810-STR	ALARM STROBE	outside					1	Winter Watchman Strobe Light	
3	FAF	60810	CC810-FAF-1	FORCED AIR FURNACE				1	1		T-stat status, Duct temp	
8	EF	60810	CC810-EF-1	EXHAUST FAN					2		ss status, proof (Monitoring only)	
8	EF	60810	CC810-EF-2	EXHAUST FAN					2		ss status, proof (Monitoring only)	
9	EH	60810	CC810-EH-1	HEATER, ELECTRIC				1	1		ss, proof (t-stat cmd, AMPS out)	
4	FAS	60810	CC810-FAS-1	FIRE ALARM SYSTEM					3		Trouble, Supervisory, Alarm (have not verified availability)	
5	LIFT	60810	CC810-SP-1	Condensate Lift PUMP					1		Leak Detector	
9	UH	60810	CC810-UH-1	UNIT HEATER				1	1		ss, proof (t-stat cmd, temp out)	
9	UH	60810	CC810-UH-2	UNIT HEATER				1	1		ss, proof (t-stat cmd, temp out)	
5	WH	60810	CC810-WH-1-R01	HOT WATER HEATER, ELECTRIC					1		Temp	
5	WH	60810	CC810-WH-2	HOT WATER HEATER, ELECTRIC					1		Temp	
1	RMT	60808	CC808-RMT	Room Temps					3		room temp sensors	Need to Verify T-Stat count
1	STROBE	60808	CC808-STR	ALARM STROBE	outside					1	Winter Watchman Strobe Light	
3	FAF	60808	CC808-FAF-1	FORCED AIR FURNACE				1	1		T-stat status, Duct temp	
8	EF	60808	CC808-EF-1	EXHAUST FAN					2		ss status, proof (Monitoring only)	
4	FAS	60808	CC808-FAS-1	FIRE ALARM SYSTEM					3		Trouble, Supervisory, Alarm (have not verified availability)	
5	WH	60808	CC808-WH-1	HOT WATER HEATER, ELECTRIC					1		Temp	

1	RMT	60806	CC806-RMT	Room Temps				3			room temp sensors	Need to Verify T-Stat count
1	STROBE	60806	CC806-STR	ALARM STROBE	outside					1	Winter Watchman Strobe Light	
3	FAF	60806	CC806-FAF-1	FORCED AIR FURNACE				1	1		T-stat status, Duct temp	
8	EF	60806	CC806-EF-1	EXHAUST FAN					2		ss status, proof (Monitoring only)	
4	FAS	60806	CC806-FAS-1	FIRE ALARM SYSTEM					3		Trouble, Supervisory, Alarm (have not verified availability)	
5	WH	60806	CC806-WH-1	HOT WATER HEATER, ELECTRIC				1			Temp	

1	RMT	60802	CC802-RMT	Room Temps				3			T-Stats for Zone Valves	Need to Verify T-Stat count
1	STROBE	60802	CC802-STR	ALARM STROBE	outside					1	Winter Watchman Strobe Light	
2	BFEP	60802	CC802-BFEP-1	BOILER FEED PUMP		AXIOM MF-200		1	1		Glycol Level alarm	
2	CP	60802	CC802-CP-1	CIRCULATING PUMP				1	1		ss status, proof (Monitoring only)	
2	CP	60802	CC802-CP-1A	CIRCULATING PUMP				1	1		ss status, proof (Monitoring only)	
2	CP	60802	CC802-CP-2	CIRCULATING PUMP				1	1		ss status, proof (Monitoring only)	
2	CP	60802	CC802-CP-3	CIRCULATING PUMP				1	1		ss status, proof (Monitoring only)	
3	FAF	60802	CC802-FAF-1	FORCED AIR FURNACE				1	1		T-stat status, Duct temp	
	ZONE	60802		Hydronic Heating System								Need count of T-stats, Zone Valves
1	BLR	60802	CC802-GB-1	BOILER, GAS				3	2	1	Supply temp, Return temp, Pressure, Run proof, Alarm, SS	
2	HRV2	60802	CC802-HRV-1	HEAT RECOVERY VENTILATOR 2 coils				1	3	1	SS, proof, discharge temp, heat coil actuator, Low Temp sw, ALARM	
8	EF	60802	CC802-EF-1	EXHAUST FAN					2		ss status, proof (Monitoring only)	
8	EF	60802	CC802-EF-2	EXHAUST FAN					2		ss status, proof (Monitoring only)	
8	EF	60802	CC802-EF-3	EXHAUST FAN					2		ss status, proof (Monitoring only)	
8	EF	60802	CC802-EF-4	EXHAUST FAN					2		ss status, proof (Monitoring only)	
4	FAS	60802	CC802-FAS-1	FIRE ALARM SYSTEM					3		Trouble, Supervisory, Alarm (have not verified availability)	
5	WH	60802	CC802-WH-1	HOT WATER HEATER, ELECTRIC				1			Temp	
5	WH	60802	CC802-WH-1-R01	HOT WATER HEATER, GAS		RHEEM 82V52-2		1			Temp	
5	WH-I	60802	CC802-WH-2	HOT WATER HEATER, INDIRECT		AMTROL BOILER MATE		1			Temp	

1	RMT	57503	CC503-RMT	Room Temps				3			T-Stats for Zone Valves	Need to Verify T-Stat count
1	STROBE	57503	CC503-STR	ALARM STROBE	outside					1	Winter Watchman Strobe Light	
2	BFEP	57503	CC503-BFEP-1	BOILER FEED PUMP		AXIOM MF-200		1	1		Glycol Level alarm	
2	CP	57503	CC503-CP-1	CIRCULATING PUMP				1	1		ss status, proof (Monitoring only)	
2	CP	57503	CC503-CP-2	CIRCULATING PUMP				1	1		ss status, proof (Monitoring only)	
	ZONE	57503		Hydronic Heating System								Need count of T-stats, Zone Valves
1	BLR	57503	CC503-GB-1	BOILER, GAS				3	2	1	Supply temp, Return temp, Pressure, Run proof, Alarm, SS	
8	EF	57503	CC503-EF-1	EXHAUST FAN					2		ss status, proof (Monitoring only)	
8	EF	57503	CC503-EF-2	EXHAUST FAN					2		ss status, proof (Monitoring only)	
4	FAS	57503	CC503-FAS-1	FIRE ALARM SYSTEM					3		Trouble, Supervisory, Alarm (have not verified availability)	
9	UH	57503	CC503-UH-1	UNIT HEATER, GLYCOL				1	1		ss, proof (t-stat cmd, temp out)	
5	WH	57503	CC503-WH-1	HOT WATER HEATER, GAS				1			Temp	

1	RMT	57400	CC400-RMT	Room Temps				3			room temp sensors	Need to Verify T-Stat count
1	STROBE	57400	CC400-STR	ALARM STROBE	outside					1	Winter Watchman Strobe Light	
3	FAF	57400	CC400-FAF-1	FORCED AIR FURNACE				1	1		T-stat status, Duct temp	
3	FAF	57400	CC400-FAF-2	FORCED AIR FURNACE				1	1		T-stat status, Duct temp	
8	EF	57400	CC503-EF-1	EXHAUST FAN					2		ss status, proof (Monitoring only)	
8	EF	57400	CC503-EF-2	EXHAUST FAN					2		ss status, proof (Monitoring only)	
4	FAS	57400	CC503-FAS-1	FIRE ALARM SYSTEM					3		Trouble, Supervisory, Alarm (have not verified availability)	
9	UH	57400	CC503-UH-1	UNIT HEATER, GLYCOL				1	1		ss, proof (t-stat cmd, temp out)	
5	WH	57400	CC503-WH-1	HOT WATER HEATER, GAS				1			Temp	

1	RMT	57402	CC402-RMT	Room Temps				3			room temp sensors	Need to Verify T-Stat count
1	STROBE	57402	CC402-STR	ALARM STROBE	outside					1	Winter Watchman Strobe Light	
1	GEN	57402	CC402-EMGEN-1	EMERGENCY GENERATOR		NO INFO	maybe	1	4		ss status, proof, tank level, leak sensor, alarm, oil pressure, water temp	
9	EH	57402	CC402-EH-1	HEATER, ELECTRIC				1	1		ss, proof (t-stat cmd, AMPS out)	
9	EH	57402	CC402-EH-2	HEATER, ELECTRIC				1	1		ss, proof (t-stat cmd, AMPS out)	
9	EH	57402	CC402-EH-3	HEATER, ELECTRIC				1	1		ss, proof (t-stat cmd, AMPS out)	
9	EH	57402	CC402-EH-4	HEATER, ELECTRIC				1	1		ss, proof (t-stat cmd, AMPS out)	
4	FAS	57402	CC402-FAS-1	FIRE ALARM SYSTEM					3		Trouble, Supervisory, Alarm (have not verified availability)	

1	RMT	57406	CC406-RMT	Room Temps			3		room temp sensors	Need to Verify T-Stat count
9	UH	57406	CC406-UH-1	UNIT HEATER, GAS			1	1	ss, proof (t-stat cmd, temp out)	
9	UH	57406	CC406-UH-2	UNIT HEATER, GAS			1	1	ss, proof (t-stat cmd, temp out)	
9	UH	57406	CC406-UH-3	UNIT HEATER, GAS			1	1	ss, proof (t-stat cmd, temp out)	
9	UH	57406	CC406-UH-4	UNIT HEATER, GAS			1	1	ss, proof (t-stat cmd, temp out)	
1	STROBE	57406	CC406-STR	ALARM STROBE	outside				1 Winter Watchman Strobe Light	
9	UH	57406	CC406-UH-1	UNIT HEATER, GAS			1	1	ss, proof (t-stat cmd, temp out)	
9	UH	57406	CC406-UH-2	UNIT HEATER, GAS			1	1	ss, proof (t-stat cmd, temp out)	
9	UH	57406	CC406-UH-3	UNIT HEATER, GAS			1	1	ss, proof (t-stat cmd, temp out)	
9	UH	57406	CC406-UH-4	UNIT HEATER, GAS			1	1	ss, proof (t-stat cmd, temp out)	
4	FAS	57406	CC406-FAS-1	FIRE ALARM SYSTEM				3	Trouble, Supervisory, Alarm (have not verified availability)	

1	RMT	57408	CC408-RMT	Room Temps			3		room temp sensors	Need to Verify T-Stat count
1	STROBE	57408	CC408-STR	ALARM STROBE	outside				1 Winter Watchman Strobe Light	
8	EF	57408	CC408-EF-1	EXHAUST FAN				2	ss status, proof (Monitoring only)	
8	EF	57408	CC408-EF-2	EXHAUST FAN				2	ss status, proof (Monitoring only)	
4	FAS	57408	CC408-FAS-1	FIRE ALARM SYSTEM				3	Trouble, Supervisory, Alarm (have not verified availability)	
9	UH	57408	CC408-UH-1	UNIT HEATER, GAS			1	1	ss, proof (t-stat cmd, temp out)	
9	UH	57408	CC408-UH-2	UNIT HEATER, GAS			1	1	ss, proof (t-stat cmd, temp out)	
9	UH	57408	CC408-UH-3	UNIT HEATER, GAS			1	1	ss, proof (t-stat cmd, temp out)	
9	UH	57408	CC408-UH-4	UNIT HEATER, GAS			1	1	ss, proof (t-stat cmd, temp out)	
5	WH	57408	CC408-WH-1	HOT WATER HEATER, ELECTRIC			1		Temp	
5	WH	57408	CC408-WH-2	HOT WATER HEATER, ELECTRIC			1		Temp	

1	RMT	57410	CC410-RMT	room temps			3		room temp sensors	Need to Verify T-Stat count
1	STROBE	57410	CC410-STR	ALARM STROBE	outside				1 Winter Watchman Strobe Light	
8	EF	57410	CC410-EF-1	EXHAUST FAN				2	ss status, proof (Monitoring only)	
8	EF	57410	CC410-EF-2	EXHAUST FAN				2	ss status, proof (Monitoring only)	
4	FAS	57410	CC410-FAS-01	FIRE ALARM SYSTEM				3	Trouble, Supervisory, Alarm (have not verified availability)	
9	UH	57410	CC410-UH-1	UNIT HEATER, GAS			1	1	ss, proof (t-stat cmd, temp out)	
9	UH	57410	CC410-UH-2	UNIT HEATER, GAS			1	1	ss, proof (t-stat cmd, temp out)	
9	UH	57410	CC410-UH-3	UNIT HEATER, GAS			1	1	ss, proof (t-stat cmd, temp out)	
9	UH	57410	CC410-UH-4	UNIT HEATER, GAS			1	1	ss, proof (t-stat cmd, temp out)	
5	WH	57410	CC410-WH-1	HOT WATER HEATER, ELECTRIC			1		Temp	
5	WH	57410	CC410-WH-2	HOT WATER HEATER, ELECTRIC			1		Temp	

1	RMT	57428	CC428-RMT	Room Temps			3		room temp sensors	Need to Verify T-Stat count
1	STROBE	57428	CC428-STR	ALARM STROBE	outside				1 Winter Watchman Strobe Light	
1	GEN	57428	CC428-EMGEN-1	EMERGENCY GENERATOR		maybe	1	4	ss status, proof, tank level, leak sensor, alarm, oil pressure, water temp	
3	FAF	57428	CC428-FAF-1-R01	FORCED AIR FURNACE			1	1	T-stat status, Duct temp	
3	FAF	57428	CC428-FAF-2-R01	FORCED AIR FURNACE			1	1	T-stat status, Duct temp	
3	FAF	57428	CC428-FAF-3-R01	FORCED AIR FURNACE			1	1	T-stat status, Duct temp	
3	FAF	57428	CC428-FAF-4-R01	FORCED AIR FURNACE			1	1	T-stat status, Duct temp	
3	FAF	57428	CC428-FAF-5-R01	FORCED AIR FURNACE			1	1	T-stat status, Duct temp	
3	FAF	57428	CC428-FAF-6	FORCED AIR FURNACE			1	1	T-stat status, Duct temp	
8	EF	57428	CC428-EF-1	EXHAUST FAN				2	ss status, proof (Monitoring only)	
8	EF	57428	CC428-EF-2	EXHAUST FAN				2	ss status, proof (Monitoring only)	
8	EF	57428	CC428-EF-3	EXHAUST FAN				2	ss status, proof (Monitoring only)	
8	EF	57428	CC428-EF-4	EXHAUST FAN				2	ss status, proof (Monitoring only)	
8	EF	57428	CC428-EF-5	EXHAUST FAN				2	ss status, proof (Monitoring only)	
8	EF	57428	CC428-EF-7	EXHAUST FAN				2	ss status, proof (Monitoring only)	
8	EF	57428	CC428-EF-8	EXHAUST FAN				2	ss status, proof (Monitoring only)	
8	EF	57428	CC428-EF-9	EXHAUST FAN				2	ss status, proof (Monitoring only)	
9	EH	57428	CC428-EH-1	HEATER, ELECTRIC			1	1	ss, proof (t-stat cmd, AMPS out)	
4	FAS	57428	CC428-FAS-1	FIRE ALARM SYSTEM				3	Trouble, Supervisory, Alarm (have not verified availability)	
6	LIFT	57428	CC428-SLS-1	Gray water LIFT pump				1	Leak Detector	
6	LIFT	57428	CC428-SLS-2	Gray water LIFT pump				1	Leak Detector	
9	SF	57428	CC428-VF-1	VENTILATING/SUPPLY AIR FAN						

5	WH	57428	CC428-WH-1-R01	HOT WATER HEATER, ELECTRIC				1		Temp	
5	WH	57428	CC428-WH-3	HOT WATER HEATER, ELECTRIC				1		Temp	
1	RMT	60700	CC700-RMT	Room Temps				4		room temp sensors	Need to Verify T-Stat count
1	STROBE	60700	CC700-STR	ALARM STROBE	outside				1	Winter Watchman Strobe Light	
3	FAF	60700	CC700-FAF-1-R01	FORCED AIR FURNACE		Day Night N80ESN1552420A		1	1	T-stat status, Duct temp	
8	EF	60700	CC700-EF-1	EXHAUST FAN					2	ss status, proof (Monitoring only)	
4	FAS	60700	CC700-FAS-1	FIRE ALARM SYSTEM					3	Trouble, Supervisory, Alarm (have not verified availability)	
5	WH	60700	CC700-WH-1	HOT WATER HEATER, ELECTRIC				1		Temp	
2	ACD	60702	CC702-ACD-1	AIR CONDITIONER	storage rm		maybe	1	1	Alarm, SAT	
1	RMT	60702	CC702-RMT	Room Temps				5		room temp sensors	Need to Verify T-Stat count
1	STROBE	60702	CC702-STR	ALARM STROBE	outside				1	Winter Watchman Strobe Light	
3	FAF	60702	CC702-FAF-1	FORCED AIR FURNACE		LENNOX M-G12Q41373		1	1	T-stat status, Duct temp	
3	FAF	60702	CC702-FAF-2	FORCED AIR FURNACE		LENNOX, M-G12Q41373		1	1	T-stat status, Duct temp	
8	EF	60702	CC702-EF-1	EXHAUST FAN					2	ss status, proof (Monitoring only)	
4	FAS	60702	CC702-FAS-1	FIRE ALARM SYSTEM					3	Trouble, Supervisory, Alarm (have not verified availability)	
5	WH	60702	CC702-WH-1	HOT WATER HEATER, ELECTRIC				1		Temp	
1	RMT	60704	CC704-RMT	Room Temps				5		room temp sensors	Need to Verify T-Stat count
1	STROBE	60704	CC704-STR	ALARM STROBE	outside				1	Winter Watchman Strobe Light	
3	FAF	60704	CC704-FAF-1	FORCED AIR FURNACE		MFG- COLEMANMDL- BGU1502		1	1	T-stat status, Duct temp	
3	FAF	60704	CC704-FAF-1-R01	FORCED AIR FURNACE		Day Night N80ESN1552420A		1	1	T-stat status, Duct temp	
8	EF	60704	CC704-EF-1	EXHAUST FAN					2	ss status, proof (Monitoring only)	
8	EF	60704	CC704-EF-2	EXHAUST FAN					2	ss status, proof (Monitoring only)	
8	EF	60704	CC704-EF-3	EXHAUST FAN					2	ss status, proof (Monitoring only)	
4	FAS	60704	CC704-FAS-1	FIRE ALARM SYSTEM					3	Trouble, Supervisory, Alarm (have not verified availability)	
5	WH	60704	CC704-WH-1	HOT WATER HEATER, ELECTRIC				1		Temp	
1	RMT	60706	CC706-RMT	Room Temps				6		room temp sensors	Need to Verify T-Stat count
1	STROBE	60706	CC706-STR	ALARM STROBE	outside				1	Winter Watchman Strobe Light	
3	FAF	60706	CC706-FAF-1-R01	FORCED AIR FURNACE		Day Night N80ESN1552420A		1	1	T-stat status, Duct temp	
4	FAS	60706	CC706-FAS-1	FIRE ALARM SYSTEM					3	Trouble, Supervisory, Alarm (have not verified availability)	
5	WH	60706	CC706-WH-1	HOT WATER HEATER, ELECTRIC				1		Temp	
1	RMT	60708	CC708-RMT	Room Temps				6		room temp sensors	Need to Verify T-Stat count
1	STROBE	60708	CC708-STR	ALARM STROBE	outside				1	Winter Watchman Strobe Light	
3	FAF	60708	CC708-FAF-1A	FORCED AIR FURNACE		Day Night N80ESN1552420A		1	1	T-stat status, Duct temp	
8	EF	60708	CC708-EF-1	EXHAUST FAN					2	ss status, proof (Monitoring only)	
4	FAS	60708	CC708-FAS-1	FIRE ALARM SYSTEM					3	Trouble, Supervisory, Alarm (have not verified availability)	
5	WH	60708	CC708-WH-1A	HOT WATER HEATER, ELECTRIC				1		Temp	
1	RMT	60710	CC710-RMT	Room Temps				4		room temp sensors	Need to Verify T-Stat count
1	STROBE	60710	CC710-STR	ALARM STROBE	outside				1	Winter Watchman Strobe Light	
3	FAF	60710	CC710-FAF-1	FORCED AIR FURNACE		Day Night N80ESN1552420A		1	1	T-stat status, Duct temp	
8	EF	60710	CC710-EF-1	EXHAUST FAN					2	ss status, proof (Monitoring only)	
8	EF	60710	CC710-EF-2	EXHAUST FAN					2	ss status, proof (Monitoring only)	
8	EF	60710	CC710-EF-3	EXHAUST FAN					2	ss status, proof (Monitoring only)	
4	FAS	60710	CC710-FAS-1	FIRE ALARM SYSTEM					3	Trouble, Supervisory, Alarm (have not verified availability)	
5	WH	60710	CC710-WH-1	HOT WATER HEATER, ELECTRIC				1		Temp	
1	RMT	60712	CC712-RMT	Room Temps				3		room temp sensors	Need to Verify T-Stat count
1	STROBE	60712	CC712-STR	ALARM STROBE	outside				1	Winter Watchman Strobe Light	
3	FAF	60712	CC712-FAF-1	FORCED AIR FURNACE		LENNOX M-G12Q31104 S-588!		1	1	T-stat status, Duct temp	
8	EF	60712	CC712-EF-1	EXHAUST FAN					2	ss status, proof (Monitoring only)	
4	FAS	60712	CC712-FAS-1	FIRE ALARM SYSTEM					3	Trouble, Supervisory, Alarm (have not verified availability)	
5	WH	60712	CC712-WH-1	HOT WATER HEATER, GAS				1		Temp	
5	WH	60712	CC712-WH-2	HOT WATER HEATER, GAS				1		Temp	
5	WH	60712	CC712-WH-3	HOT WATER HEATER, GAS				1		Temp	

1	RMT	60714-740	CC714,740-RMT	BLDG CC714 CC740 room temps				5				room temp sensors	Need to Verify T-Stat count
1	STROBE	60714-740	CC714,740-STR	ALARM STROBE	outside					1		1 Winter Watchman Strobe Light	
3	FAF	60714-740	CC714-FAF-1	FORCED AIR FURNACE		LENOX M-G12Q51373- S# 588	1	1				T-stat status, Duct temp	
3	FAF	60714-740	CC714-FAF-2	FORCED AIR FURNACE		LENNOX M-G12Q5-137-3- S# 5	1	1				T-stat status, Duct temp	
3	FAF	60714-740	CC740-FAF-1	FORCED AIR FURNACE		COLEMAN EVCON, MDL- BGU 1	1	1				T-stat status, Duct temp	
8	EF	60714-740	CC714-EF-1	EXHAUST FAN							2	ss status, proof (Monitoring only)	
4	FAS	60714-740	CC714-FAS-1	FIRE ALARM SYSTEM							3	Trouble, Supervisory, Alarm (have not verified availability)	
5	WH	60714-740	CC714-WH-1-R01	HOT WATER HEATER, GAS				1				Temp	
4	FAS	60714-740	CC740-FAS-1	FIRE ALARM SYSTEM							3	Trouble, Supervisory, Alarm (have not verified availability)	

1	RMT	60716-718	CC716, 718-RMT	BLDG CC716 CC716L CC718 room temps				7				room temp sensors	Need to Verify T-Stat count
1	STROBE	60716-718	CC716, 718-STR	ALARM STROBE	outside					1		1 Winter Watchman Strobe Light	
3	FAF	60716-718	CC716-FAF-1	FORCED AIR FURNACE		MFG- COLEMAN EVCON, MDL- I	1	1				T-stat status, Duct temp	
2	HRV	60716-718	CC716-HRV-1	HEAT RECOVERY VENTILATOR			1	3	1	1		SS, proof, discharge temp, heat coil actuator, Low Temp sw, ALARM	
3	FAF	60716-718	CC716-FAF-1-R01	FORCED AIR FURNACE		Day Night N80ESN1102120A2	1	1				T-stat status, Duct temp	
3	FAF	60716-718	CC716L-FAF-1	FORCED AIR FURNACE		MFG- LENNOX, MDL- G21Q4/5-	1	1				T-stat status, Duct temp	
3	FAF	60716-718	CC718-FAF-1	FORCED AIR FURNACE		MFG-TRANE XR-80, MDL-TUD1I	1	1				T-stat status, Duct temp	
2	HRV	60716-718	CC718-HRV-1	HEAT RECOVERY VENTILATOR		VENMAR AVS	1	3	1	1		SS, proof, discharge temp, heat coil actuator, Low Temp sw, ALARM	
4	FAS	60716-718	CC716-FAS-1	FIRE ALARM SYSTEM							3	Trouble, Supervisory, Alarm (have not verified availability)	
8	EF	60716-718	CC716L-EF-1	EXHAUST FAN							2	ss status, proof (Monitoring only)	
8	EF	60716-718	CC716L-EF-2	EXHAUST FAN							2	ss status, proof (Monitoring only)	
9	UH	60716-718	CC716L-UH-1	UNIT HEATER, GAS			1	1				ss, proof (t-stat cmd, temp out)	
9	UH	60716-718	CC716L-UH-1-R01	UNIT HEATER, GAS			1	1				ss, proof (t-stat cmd, temp out)	
5	WH	60716-718	CC716L-WH-1	HOT WATER HEATER, GAS			1					Temp	
5	WH	60716-718	CC716L-WH-2	HOT WATER HEATER, GAS			1					Temp	
4	FAS	60716-718	CC718-FAS-1	FIRE ALARM SYSTEM							3	Trouble, Supervisory, Alarm (have not verified availability)	

1	RMT	60720-722	CC720, 722-RMT	BLDG CC720 CC720L CC722				7				room temp sensors	Need to Verify T-Stat count
1	STROBE	60720-722	CC720, 722-STR	ALARM STROBE	outside					1		1 Winter Watchman Strobe Light	
3	FAF	60720-722	CC720-FAF-1-R01	FORCED AIR FURNACE		TRANE XR80	1	1				T-stat status, Duct temp	
2	HRV	60720-722	CC720-HRV-1	HEAT RECOVERY VENTILATOR		VENMAR, MDL - 43135,	1	3	1	1		SS, proof, discharge temp, heat coil actuator, Low Temp sw, ALARM	
3	MUA	60720-722	CC720-MUA-1	MAKEUP AIR UNIT		GREEN HECK, MDL - DG-109-H1	2	2			2	SS status, run status, DAT, Alarm, cfm, dirty filter	
3	FAF	60720-722	CC720L-FAF-1	FORCED AIR FURNACE		LENNOX, PULSE 21, MDL- G21C	1	1				T-stat status, Duct temp	
3	FAF	60720-722	CC720L-FAF-2	FORCED AIR FURNACE	verify	can't find this, supposedly a len	1	1				T-stat status, Duct temp	
3	FAF	60720-722	CC722-FAF-1-R01	FORCED AIR FURNACE		MFG- TRANE, MDL - TUD1D140.	1	1				T-stat status, Duct temp	
2	HRV	60720-722	CC722-HRV-1	HEAT RECOVERY VENTILATOR		MFG - VENMAR, MDL - 43135	1	3	1	1		SS, proof, discharge temp, heat coil actuator, Low Temp sw, ALARM	
3	MUA	60720-722	CC722-MUA-1	MAKEUP AIR UNIT		MFG - GREEN HECK, MDL - DG-1	2	2			2	SS status, run status, DAT, Alarm, cfm, dirty filter	
8	EF	60720-722	CC720-EF-1	EXHAUST FAN							2	ss status, proof (Monitoring only)	
8	EF	60720-722	CC720-EF-2	EXHAUST FAN							2	ss status, proof (Monitoring only)	
8	EF	60720-722	CC720-EF-3	EXHAUST FAN							2	ss status, proof (Monitoring only)	
8	EF	60720-722	CC720-EF-4	EXHAUST FAN							2	ss status, proof (Monitoring only)	
8	EF	60720-722	CC720-EF-5	EXHAUST FAN							2	ss status, proof (Monitoring only)	
8	EF	60720-722	CC720-EF-6	EXHAUST FAN							2	ss status, proof (Monitoring only)	
4	FAS	60720-722	CC720-FAS-1	FIRE ALARM SYSTEM							3	Trouble, Supervisory, Alarm (have not verified availability)	
2	CP	60720-722	CC720L-CP-1	CIRCULATING PUMP			1	1				ss status, proof (Monitoring only)	
8	EF	60720-722	CC720L-EF-1	EXHAUST FAN							2	ss status, proof (Monitoring only)	
8	EF	60720-722	CC720L-EF-2	EXHAUST FAN							2	ss status, proof (Monitoring only)	
8	EF	60720-722	CC720L-EF-3	EXHAUST FAN							2	ss status, proof (Monitoring only)	
9	UH	60720-722	CC720L-UH-1	UNIT HEATER, GAS			1	1				ss, proof (t-stat cmd, temp out)	
9	UH	60720-722	CC720L-WH-1	UNIT HEATER, GAS			1	1				ss, proof (t-stat cmd, temp out)	
5	WH	60720-722	CC720L-WH-2	HOT WATER HEATER, GAS			1					Temp	

1	RMT	60724-726	CC724, 726-RMT	BLDG CC724, 724L, 726 room temps				6				room temp sensors	Need to Verify T-Stat count
3	FAF	60724-726	CC724-FAF-1	FORCED AIR FURNACE	verify	COLEMAN/EVCON- MDL-BGU15	1	1				T-stat status, Duct temp	
2	BFEP	60724-726	CC724L-BFEP-1	BOILER FEED PUMP		AXIOM MF-200	1	1				Glycol Level alarm	
2	CP	60724-726	CC724L-CP-1	CIRCULATING PUMP		GRUNDFOS, MDL-UPS 26-99FC,	1	1				ss status, proof (Monitoring only)	
2	CP	60724-726	CC724L-CP-2	CIRCULATING PUMP, BOILER		MFG- TACO, MDL- 0010-F1-1IFC	1	1				ss status, proof (Monitoring only)	
2	CP	60724-726	CC724L-CP-3	CIRCULATING PUMP, HEATING COIL		MFG- TACO, MDL- 0014-F1-1IFC	1	1				ss status, proof (Monitoring only)	

2	CP	60724-726	CC724L-CP-4	CIRCULATING PUMP (RADIANT)	MFG- TACO, MDL- 0010-F1-1IFC	1	1			ss status, proof (Monitoring only)	
	ZONE	60724-726		Hydronic Heating System							Need count of T-stats, Zone Valves
1	BLR	60724-726	CC724L-GB-1	BOILER, GAS	MFG- LOCHINVAR, MDL- WBN1	3	2		1	Supply temp, Return temp, Pressure, Run proof, Alarm, SS	
2	HRV2	60724-726	CC724L-HRV-1	HEAT RECOVERY VENTILATOR 2 coils	XETEX, MDL- XHR-20C-18-PHW	1	3	2	1	SS, proof, discharge temp, 2 heat coil actuators, Low Temp sw, ALARM	
3	WH-HE	60724-726	CC724L-WH-1	HOT WATER HEATER, GAS	MFG- RINNAI, MDL- RC98HP		1			Dry contact Alarm input (have not verified availability)	
3	WH-HE	60724-726	CC724L-WH-2	HOT WATER HEATER, GAS	MFG- RINNAI, MDL- RC98HP		1			Dry contact Alarm input (have not verified availability)	
3	WH-HE	60724-726	CC724L-WH-3	HOT WATER HEATER, GAS	MFG- RINNAI, MDL- RC98HP		1			Dry contact Alarm input (have not verified availability)	
3	WH-HE	60724-726	CC724L-WH-4	HOT WATER HEATER, GAS	MFG- RINNAI, MDL- RC98HP		1			Dry contact Alarm input (have not verified availability)	
3	WH-HE	60724-726	CC724L-WH-5	HOT WATER HEATER, GAS	MFG- RINNAI, MDL- RC98HP		1			Dry contact Alarm input (have not verified availability)	
3	WH-HE	60724-726	CC724L-WH-6	HOT WATER HEATER, GAS	MFG- RINNAI, MDL- RC98HP		1			Dry contact Alarm input (have not verified availability)	
3	FAF	60724-726	CC726-FAF-1	FORCED AIR FURNACE						T-stat status, Duct temp	
1	STROBE	60724-726	CC724, 726-STR	ALARM STROBE	verify outside	1	1		1	Winter Watchman Strobe Light	
4	FAS	60724-726	CC724-FAS-1	FIRE ALARM SYSTEM					3	Trouble, Supervisory, Alarm (have not verified availability)	
8	EF	60724-726	CC724L-EF-1	EXHAUST FAN					2	ss status, proof (Monitoring only)	
8	EF	60724-726	CC724L-EF-2	EXHAUST FAN					2	ss status, proof (Monitoring only)	
3	FAF	60724-726	CC724L-FAF-1	FORCED AIR FURNACE		1	1			T-stat status, Duct temp	
9	UH	60724-726	CC724L-UH-1	UNIT HEATER, GAS		1	1			ss, proof (t-stat cmd, temp out)	
8	EF	60724-726	CC726-EF-1	EXHAUST FAN					2	ss status, proof (Monitoring only)	
4	FAS	60724-726	CC726-FAS-1	FIRE ALARM SYSTEM					3	Trouble, Supervisory, Alarm (have not verified availability)	
1	RMT	60728-730	CC728, 730-RMT	BLDG CC728, 728L, 730 room temps		6				room temp sensors	Need to Verify T-Stat count
3	FAF	60728-730	CC728-FAF-1	FORCED AIR FURNACE	MFG - TRANE, MDL-1	1	1			T-stat status, Duct temp	
2	HRV	60728-730	CC728-HRV-1	HEAT RECOVERY VENTILATOR	MFG - VENMAR, MD	1	3	1	1	SS, proof, discharge temp, heat coil actuator, Low Temp sw, ALARM	
2	BFEP	60728-730	CC728L-BFEP-1	BOILER FEED PUMP	AXIOM MF-200	1	1			Glycol Level alarm	
2	CP	60728-730	CC728L-CP-1	CIRCULATING PUMP	GRUNDFOS, MDL-UP	1	1			ss status, proof (Monitoring only)	
2	CP	60728-730	CC728L-CP-2	CIRCULATING PUMP, BOILER	MFG- TACO, MDL- 0C	1	1			ss status, proof (Monitoring only)	
2	CP	60728-730	CC728L-CP-3	CIRCULATING PUMP, HEATING COIL	MFG- TACO, MDL- 0C	1	1			ss status, proof (Monitoring only)	
2	CP	60728-730	CC728L-CP-4	CIRCULATING PUMP (RADIANT)	MFG- TACO, MDL- 0C	1	1			ss status, proof (Monitoring only)	
	ZONE	60728-730		Hydronic Heating System							Need count of T-stats, Zone Valves
1	BLR	60728-730	CC728L-GB-1	BOILER, GAS	MFG- LOCHINVAR, MDL- WBN1	3	2		1	Supply temp, Return temp, Pressure, Run proof, Alarm, SS	
2	HRV2	60728-730	CC728L-HRV-1	HEAT RECOVERY VENTILATOR 2 coils	XETEX, MDL- XHR-20C-18-PHW	1	3	2	1	SS, proof, discharge temp, 2 heat coil actuators, Low Temp sw, ALARM	
3	WH-HE	60728-730	CC728L-WH-3	HOT WATER HEATER, GAS	MFG- RINNAI, MDL- RC98HP		1			Dry contact Alarm input (have not verified availability)	
3	WH-HE	60728-730	CC728L-WH-4	HOT WATER HEATER, GAS	MFG- RINNAI, MDL- RC98HP		1			Dry contact Alarm input (have not verified availability)	
3	WH-HE	60728-730	CC728L-WH-5	HOT WATER HEATER, GAS	MFG- RINNAI, MDL- RC98HP		1			Dry contact Alarm input (have not verified availability)	
3	WH-HE	60728-730	CC728L-WH-6	HOT WATER HEATER, GAS	MFG- RINNAI, MDL- RC98HP		1			Dry contact Alarm input (have not verified availability)	
3	WH-HE	60728-730	CC728L-WH-7	HOT WATER HEATER, GAS	MFG- RINNAI, MDL- RC98HP		1			Dry contact Alarm input (have not verified availability)	
3	WH-HE	60728-730	CC728L-WH-8	HOT WATER HEATER, GAS	MFG- RINNAI, MDL- RC98HP		1			Dry contact Alarm input (have not verified availability)	
3	FAF	60728-730	CC730-FAF-1	FORCED AIR FURNACE	MFG - TRANE XR-80, MDL - TUD	1	1			T-stat status, Duct temp	
2	HRV	60728-730	CC730-HRV-1	HEAT RECOVERY VENTILATOR	MFG - VENMAR, MDL - HE 1.8	1	3	1	1	SS, proof, discharge temp, heat coil actuator, Low Temp sw, ALARM	
1	STROBE	60728-730	CC728, 730-STR	ALARM STROBE	outside				1	Winter Watchman Strobe Light	
4	FAS	60728-730	CC728-FAS-1	FIRE ALARM SYSTEM					3	Trouble, Supervisory, Alarm (have not verified availability)	
8	EF	60728-730	CC728L-EF-1	EXHAUST FAN					2	ss status, proof (Monitoring only)	
8	EF	60728-730	CC728L-EF-2	EXHAUST FAN					2	ss status, proof (Monitoring only)	
9	UH	60728-730	CC728L-UH-1	UNIT HEATER		1	1			ss, proof (t-stat cmd, temp out)	
4	FAS	60728-730	CC730-FAS-1	FIRE ALARM SYSTEM					3	Trouble, Supervisory, Alarm (have not verified availability)	
1	RMT	60732-734	CC732, 734-RMT	BLDG CC732, 732L, 734 room temps		6				room temp sensors	Need to Verify T-Stat count
3	FAF	60732-734	CC732-FAF-1	FORCED AIR FURNACE	TRANE XR-80,- TUD1D140A960:	1	1			T-stat status, Duct temp	
2	HRV	60732-734	CC732-HRV-1	HEAT RECOVERY VENTILATOR	MFG - VENMAR, MDL - HE 1.8	1	3	1	1	SS, proof, discharge temp, heat coil actuator, Low Temp sw, ALARM	
2	BFEP	60732-734	CC732L-BFEP-1	BOILER FEED PUMP	AXIOM MF-200	1	1			Glycol Level alarm	
2	CP	60732-734	CC732L-CP-1	CIRCULATING PUMP	maximo only list: GRUNDFOS, MDL-UPS 26-99FC	1	1			ss status, proof (Monitoring only)	
2	CP	60732-734	CC732L-CP-2	CIRCULATING PUMP	maximo only list: MFG- TACO, MDL- 0010-F1-1IFC	1	1			ss status, proof (Monitoring only)	
2	CP	60732-734	CC732L-CP-3	CIRCULATING PUMP	maximo only list: MFG- TACO, MDL- 0014-F1-1IFC	1	1			ss status, proof (Monitoring only)	
2	CP	60732-734	cc732L-cp-4	CIRCULATING PUMP (RADIANT)	I made this up MFG- TACO, MDL- 0010-F1-1IFC	1	1			ss status, proof (Monitoring only)	
	ZONE	60732-734		Hydronic Heating System							Need count of T-stats, Zone Valves
1	BLR	60732-734	CC732L-GB-1	BOILER, GAS	MFG- LOCHINVAR, MDL- WBN1	3	2		1	Supply temp, Return temp, Pressure, Run proof, Alarm, SS	
2	HRV2	60732-734	CC732L-HRV-1	HEAT RECOVERY VENTILATOR 2 coils	XETEX, MDL- XHR-20C-18-PHW	1	3	2	1	SS, proof, discharge temp, 2 heat coil actuators, Low Temp sw, ALARM	
3	WH-HE	60732-734	CC732L-WH-1-R01	HOT WATER HEATER, GAS	MFG- RINNAI, MDL- RC98HP		1			Dry contact Alarm input (have not verified availability)	
3	WH-HE	60732-734	CC732L-WH-2-R01	HOT WATER HEATER, GAS	MFG- RINNAI, MDL- RC98HP		1			Dry contact Alarm input (have not verified availability)	

3	WH-HE	60732-734	CC732L-WH-3	HOT WATER HEATER, GAS		MFG- RINNAI, MDL- RC98HP	1										Dry contact Alarm input (have not verified availability)
3	WH-HE	60732-734	CC732L-WH-4	HOT WATER HEATER, GAS		MFG- RINNAI, MDL- RC98HP	1										Dry contact Alarm input (have not verified availability)
3	WH-HE	60732-734	CC732L-WH-5	HOT WATER HEATER, GAS		MFG- RINNAI, MDL- RC98HP	1										Dry contact Alarm input (have not verified availability)
3	WH-HE	60732-734	CC732L-WH-6	HOT WATER HEATER, GAS		MFG- RINNAI, MDL- RC98HP	1										Dry contact Alarm input (have not verified availability)
3	FAF	60732-734	CC734-FAF-1	FORCED AIR FURNACE		MFG - TRANE XR80, MDL - TUD:	1	1									T-stat status, Duct temp
2	HRV	60732-734	CC734-HRV-1	HEAT RECOVERY VENTILATOR		MFG - VENMAR AVS, MDL - HE :	1	3	1	1							SS, proof, discharge temp, heat coil actuator, Low Temp sw, ALARM
1	STROBE	60732-734	CC732, 734-STR	ALARM STROBE	outside												1 Winter Watchman Strobe Light
8	EF	60732-734	CC732L-EF-1	EXHAUST FAN													ss status, proof (Monitoring only)
8	EF	60732-734	CC732L-EF-2	EXHAUST FAN													ss status, proof (Monitoring only)
9	UH	60732-734	CC732L-UH-1	UNIT HEATER, GAS			1	1									ss, proof (t-stat cmd, temp out)
4	FAS	60732-734	CC734-FAS-1	FIRE ALARM SYSTEM													3 Trouble, Supervisory, Alarm (have not verified availability)

1	RMT	60736-738	CC736, 738-RMT	BLDG CC736, 736L, 738 room temp			6										room temp sensors	Need to Verify T-Stat count
3	FAF	60736-738	CC736-FAF-1-R01	FORCED AIR FURNACE		TRANE XR80	1	1									T-stat status, Duct temp	
2	HRV	60736-738	CC736-HRV-1	HEAT RECOVERY VENTILATOR		MFG - VENMAR, MDL - 45400	1	3	1	1							SS, proof, discharge temp, heat coil actuator, Low Temp sw, ALARM	
2	BFEP	60736-738	CC736L-BFEP-1	BOILER FEED PUMP		AXIOM MF-200	1	1									Glycol Level alarm	
2	CP	60736-738	CC736L-CP-1-R01	CIRCULATING PUMP - BOILER SYSTEM PUMP -		GRUNDFOS, MDL-UPS 26-99FC	1	1									ss status, proof (Monitoring only)	
2	CP	60736-738	CC736L-CP-2A-R01	CIRCULATING PUMP, HEAT COIL FOR HRV		TACO MDL 0010-F3-1IFC	1	1									ss status, proof (Monitoring only)	
2	CP	60736-738	CC736L-CP-3	CIRCULATING PUMP - RADIANT PUMP -		MFG- TACO, MDL- 0014-F1-1IFC	1	1									ss status, proof (Monitoring only)	
2	CP	60736-738	CC736L-CP-4	CIRCULATING PUMP (RADIANT MIXING BLOCK / TEMPERING		TACOMDL - I100C35-1	1	1									ss status, proof (Monitoring only)	
	ZONE	60736-738		Hydronic Heating System														Need count of T-stats, Zone Valves
1	BLR	60736-738	CC736L-GB-1	BOILER, GAS		MFG- LOCHINVAR, MDL- WBN1	3	2									1 Supply temp, Return temp, Pressure, Run proof, Alarm, SS	
2	HRV2	60736-738	CC736L-HRV-1	HEAT RECOVERY VENTILATOR 2 coils		XETEX, MDL- XHR-20C-18-PHW	1	3	2	1							SS, proof, discharge temp, 2 heat coil actuators, Low Temp sw, ALARM	
3	WH-HE	60736-738	CC736L-WH-1-R01	HOT WATER HEATER, GAS		MFG- RINNAI, MDL- RC98HP											1 Dry contact Alarm input (have not verified availability)	
3	WH-HE	60736-738	CC736L-WH-2-R01	HOT WATER HEATER, GAS		MFG- RINNAI, MDL- RC98HP											1 Dry contact Alarm input (have not verified availability)	
3	WH-HE	60736-738	CC736L-WH-3	HOT WATER HEATER, GAS		MFG- RINNAI, MDL- RC98HP											1 Dry contact Alarm input (have not verified availability)	
3	WH-HE	60736-738	CC736L-WH-4	HOT WATER HEATER, GAS		MFG- RINNAI, MDL- RC98HP											1 Dry contact Alarm input (have not verified availability)	
3	WH-HE	60736-738	CC736L-WH-5	HOT WATER HEATER, GAS		MFG- RINNAI, MDL- RC98HP											1 Dry contact Alarm input (have not verified availability)	
3	WH-HE	60736-738	CC736L-WH-6	HOT WATER HEATER, GAS		MFG- RINNAI, MDL- RC98HP											1 Dry contact Alarm input (have not verified availability)	
3	FAF	60736-738	CC738-FAF-1	FORCED AIR FURNACE	verify	COLEMAN-EVCON	1	1									T-stat status, Duct temp	
1	STROBE	60736-738	CC736, 738-STR	ALARM STROBE	outside												1 Winter Watchman Strobe Light	
4	FAS	60736-738	CC736-FAS-1	FIRE ALARM SYSTEM													3 Trouble, Supervisory, Alarm (have not verified availability)	
8	EF	60736-738	CC736L-EF-1	EXHAUST FAN													2 ss status, proof (Monitoring only)	
8	EF	60736-738	CC736L-EF-2	EXHAUST FAN													2 ss status, proof (Monitoring only)	
5	WH-T	60736-738	CC736L-HWT-1	HOT WATER HOLDING TANK			1										Temp	
5	WH-T	60736-738	CC736L-HWT-2	HOT WATER HOLDING TANK			1										Temp	
9	UH	60736-738	CC736L-UH-1	UNIT HEATER			1	1									ss, proof (t-stat cmd, temp out)	
4	FAS	60736-738	CC738-FAS-1	FIRE ALARM SYSTEM													3 Trouble, Supervisory, Alarm (have not verified availability)	

1	RMT	60620	CC620-RMT	Room Temps			10										room temp sensors	Need to Verify T-Stat count
2	CP	60620	CC620-CP-1	CIRCULATING PUMP lead/lag	boiler room		1	1									1 ss status, proof (Monitoring and control Lead Lag))	
2	CP	60620	CC620-CP-2	CIRCULATING PUMP lead/lag	boiler room		1	1									1 ss status, proof (Monitoring and control Lead Lag))	
1	GEN	60620	CC620-EMGEN-1	EMERGENCY GENERATOR	Back of bldg	maybe	1	4									ss status, proof, tank level, leak sensor, alarm, oil pressure, water temp	
	ZONE	60620		Hydronic Heating System														Need count of T-stats, Zone Valves
1	BLR	60620	CC620-GB-1	BOILER, GAS	boiler room		3	2									1 Supply temp, Return temp, Pressure, Run proof, Alarm, SS	
	ZONE	60620		Hydronic Heating System														Need count of T-stats, Zone Valves
1	BLR	60620	CC620-GB-2	BOILER, GAS	boiler room		3	2									1 Supply temp, Return temp, Pressure, Run proof, Alarm, SS	
1	MUA	60620	CC620-MUA-2	MAKE UP AIR HANDLING UNIT	roof for dining ar		2	2									2 SS status, run status, DAT, Alarm, cfm, dirty filter	
1	MUA	60620	CC620-MUA-3	MAKE UP AIR HANDLING UNIT	roof for kitchen		2	2									2 SS status, run status, DAT, Alarm, cfm, dirty filter	
3	RU	60620	CC620-RU-1	WALK-IN REFRIGERATOR (COOLER)	kitchen		1										temp	
3	RU	60620	CC620-RU-11	WALK-IN REFRIGERATOR (COOLER)	kitchen		1										temp	
3	RU	60620	CC620-RU-12	WALK-IN FREEZER	kitchen		1	1									temp	
3	RU	60620	CC620-RU-2	REACH-IN FREEZER	kitchen		1	1									temp	
3	RU	60620	CC620-RU-4	REACH-IN REFRIGERATOR	kitchen		1										temp	
3	RU	60620	CC620-RU-7	REACH-IN REFRIGERATOR	kitchen		1										temp	
5	WH	60620	CC620-WH-1	HOT WATER HEATER, GAS	boiler room		1										Temp	
5	WH	60620	CC620-WH-2	HOT WATER HEATER, GAS	front mech		1										Temp	
1	STROBE	60620	CC620-STR	ALARM STROBE	outside												1 Winter Watchman Strobe Light	
9	CUH	60620	CC620-CUH-1	CABINET UNIT HEATER			1	1									ss, proof (t-stat cmd, temp out)	

9	CUH	60620	CC620-CUH-2	CABINET UNIT HEATER	1	1	ss, proof (t-stat cmd, temp out)	
8	EF	60620	CC620-EF-10	EXHAUST FAN		2	ss status, proof (Monitoring only)	
8	EF	60620	CC620-EF-11	EXHAUST FAN		2	ss status, proof (Monitoring only)	
8	EF	60620	CC620-EF-12	EXHAUST FAN		2	ss status, proof (Monitoring only)	
8	EF	60620	CC620-EF-2	EXHAUST FAN		2	ss status, proof (Monitoring only)	
8	EF	60620	CC620-EF-3	EXHAUST FAN		2	ss status, proof (Monitoring only)	
8	EF	60620	CC620-EF-4	EXHAUST FAN		2	ss status, proof (Monitoring only)	
8	EF	60620	CC620-EF-6	EXHAUST FAN		2	ss status, proof (Monitoring only)	
8	EF	60620	CC620-EF-7	EXHAUST FAN		2	ss status, proof (Monitoring only)	
8	EF	60620	CC620-EF-8	EXHAUST FAN		2	ss status, proof (Monitoring only)	
8	EF	60620	CC620-EF-9	EXHAUST FAN		2	ss status, proof (Monitoring only)	
2	EFK	60620	CC620-EF-5	EXHAUST FAN AND RANGE HOOD w/MUA-2 roof above Kitch	1	2	ss status, ss proof, amps	
2	EFK	60620	CC620-EF-8	EXHAUST FAN for Dishwasher w/MUA-2 roof above DW	1	2	ss status, ss proof, amps	
4	FAS	60620	CC620-FAS-1	FIRE ALARM SYSTEM		3	Trouble, Supervisory, Alarm (have not verified availability)	
4	FSS	60620	CC620-FSS-1	FIRE SUPPRESSION SYSTEM		1	Trouble (have not verified availability)	
4	FSS	60620	CC620-FSS-2	FIRE SUPPRESSION SYSTEM, ANSUL		1	Trouble (have not verified availability)	
4	FSS	60620	CC620-FSS-3	FIRE SUPPRESSION SYSTEM, CHEMICAL		1	Trouble (have not verified availability)	
3	ZONE	60620		Hydronic Heating System		10	10 cmd, pos, T-stat	Need count of T-stats, Zone Valves
9	UH	60620	CC620-UH-13	UNIT HEATER, GLYCOL	1	1	ss, proof (t-stat cmd, temp out)	
9	UH	60620	CC620-UH-14	UNIT HEATER, GLYCOL	1	1	ss, proof (t-stat cmd, temp out)	
9	UH	60620	CC620-UH-15	UNIT HEATER, GLYCOL	1	1	ss, proof (t-stat cmd, temp out)	
9	UH	60620	CC620-UH-16	UNIT HEATER, GLYCOL	1	1	ss, proof (t-stat cmd, temp out)	
9	UH	60620	CC620-UH-17	UNIT HEATER, GLYCOL	1	1	ss, proof (t-stat cmd, temp out)	
9	UH	60620	CC620-UH-18	UNIT HEATER, GLYCOL	1	1	ss, proof (t-stat cmd, temp out)	
9	UH	60620	CC620-UH-19	UNIT HEATER, GLYCOL	1	1	ss, proof (t-stat cmd, temp out)	
9	UH	60620	CC620-UH-20	UNIT HEATER, GLYCOL	1	1	ss, proof (t-stat cmd, temp out)	
9	UH	60620	CC620-UH-21	UNIT HEATER, GLYCOL	1	1	ss, proof (t-stat cmd, temp out)	
5	WH	60620	CC620-WH-1	HOT WATER HEATER, GAS	1		Temp	
5	WH	60620	CC620-WH-2	HOT WATER HEATER, GAS	1		Temp	
2	CP	58100	CC100-CP-1	PUMP, DHW recirc	1	1	ss status, proof (Monitoring only)	
3	FAF	58100	CC100-FAF-1	FORCED AIR FURNACE	1	1	T-stat status, Duct temp	
5	WH	58100	CC100-WH-1	HOT WATER HEATER, GAS	1		Temp	
1	RMT	58100	CC100-RMT	Room Temps	4		room temp sensors	Need to Verify T-Stat count
1	STROBE	58100	CC100-STR	ALARM STROBE		1	1 Winter Watchman Strobe Light	
8	EF	58100	CC100-EF-1	EXHAUST FAN		2	ss status, proof (Monitoring only)	
8	EF	58100	CC100-EF-2	EXHAUST FAN		2	ss status, proof (Monitoring only)	
4	FAS	58100	CC100-FAS-1	FIRE ALARM SYSTEM		3	Trouble, Supervisory, Alarm (have not verified availability)	
5	WH	58100	CC100-WH-1	HOT WATER HEATER, GAS	1		Temp	