



THE STATE
of **ALASKA**
GOVERNOR MIKE DUNLEAVY

Department of Military and Veterans Affairs

FMO Design and Construction

57024 Roosevelt Rd
PO Box 5169
JBER, AK 99505

Email: mvafmocontracts@alaska.gov Issue Date: 10/22/24

ATTN: Vendors

RE: **Project Name:** **BAAF Bldg.# 47420 Boiler Replacement**
 Project Number: 02A7024020
 Project Location: JBER, Alaska

****New Bid due DATE AND TIME: 10/24/24 1:00pm****

Addendum # One (1)

This addendum forms a part of the contract documents and modifies the original drawings and/or specifications for the subject work. In case of conflicts between this addendum and previously issued documents, this addendum shall take precedence.

****The Bid Due date has been extended to 10/24/24 @ 1:00pm. The following questions were asked:**

- The bid documents do not contain a bid schedule, will one be provided with an amendment to this ITB? **I will send an addendum as well as a Bid schedule out.**
- I did not see certificate of Buy American Compliance forms in the ITB, are these not applicable? **The buy American Cert is on pages 28,29 & 30.**
- Is the heating system to be flushed and cleaned? **Yes**
- Is the glycol in the system to be replaced with new, if so do you have an estimated quantity of glycol? **It is to be replaced not sure on the amount, I will include the amount in the Addendum**
- Is the exhaust vent to be completely replaced or just replaced to the extent necessary for the new boiler? **Just to extent to install the new Boiler.**

This addendum is considered part of the Invitation to Bid (ITB) and is to be acknowledge on your proposal.

Please contact me if you have any questions.

Sincerely, scott.stewart@alaska.gov

End of Addendum