



THE STATE
of **ALASKA**
GOVERNOR MIKE DUNLEAVY

**Department of Military and
Veterans Affairs**

FMO Design and Construction

57024 Roosevelt Rd
PO Box 5169
JBER, AK 99505

Email: mvafmocontracts@alaska.gov Issue Date: 10/22/24

ATTN: Vendors

RE: Project Name: BAAF Bldg.# 47420 Boiler Replacement
Project Number: 02A7024020
Project Location: JBER, Alaska

Addendum # (2)

This addendum forms a part of the contract documents and modifies the original drawings and/or specifications for the subject work. In case of conflicts between this addendum and previously issued documents, this addendum shall take precedence.

Question from Contractor: The scope of work mentions Boiler Mate of equal size (1.04 – D) Is this referencing the water heater? (often referred to as a boiler mate, but in this case the water heater is a gas fired unit) Or is this supposed to be referencing the heating system expansion tank?

****Answer: Please exclude the boiler mate.****

This addendum is considered part of the Invitation to Bid (ITB) and is to be acknowledge on your proposal.

Please contact me if you have any questions.

Sincerely, scott.stewart@alaska.gov

End of Addendum