

# STATE OF ALASKA

Department of Public Safety  
Division of Administrative Services



## Galena Fuel Tank

IFQ Number: PR25AC0702A

Amendment # 1

October 23, 2024

**This amendment is being issued to *answer questions received and extend closure date for receipt of bids.***

**Important Note to Offerors:** You must sign and return this page of the amendment document with your proposal. Failure to do so may result in the rejection of your proposal. Only the RFP terms and conditions referenced in this amendment are being changed. All other terms and conditions of the RFP remain the same.

Olivia Jewell  
Facilities Manager 1  
Phone: (907) 269-5647  
Email: [Olivia.jewell@alaska.gov](mailto:Olivia.jewell@alaska.gov)

---

COMPANY SUBMITTING PROPOSAL

---

AUTHORIZED SIGNATURE

---

DATE

**Questions submitted by potential offerors and answers from the state:**

See attached.

**Changes to the RFP:**

**Change 1:** Deadline for bids is extended to October 30, 2024, at 3:00 p.m. AKST.

	Galena Fuel Tank 25AC0702A Questions	Answers
Line #1	You mentioned being able to move the existing tanks around, do you have a forklift on site. It would save a lot of money if we did not have to transport equipment to move/ set the tank.	we do not have equipment or an operator.
Line #2	Transportation from the barge to the site. Another place we could save money and time. Do you have the means to transport the tank or would we need to barge over a truck and trailer and possibly a fork lift?	We do not have equipment or an operator.
Line #3	Is there electrical services close to the proposed location of the new tank?	The closest electric is the trooper housing, which is a couple hundred yards away
	<b>Questions 10/07-10/10/24</b>	
Line #4	Where do you intend to get power for this new fuel system? Can we get pictures of the proposed breaker panel and the distance from it to the tank?	See line #3.
Line #5	Are there any foundation requirements for the fuel tank?	Please see the IFQ under Section 2
Line #6	Will a state fire marshal review and permit be required? If so, who will be responsible for engineering and review fees if needed?	Yes, the vendor needs to see IFQSection 3.1
Line #7	Contractor to provide new 300 gallon Avgas fuel tank?	Please see the IFQ Section 1
Line #8	No demo of existing tanks required ?	Please see the IFQ Section 2, paragraph 2.1.
Line #9	Where is power for the pump to come from and is it 120 or 220 ?	See line #15.
Line #10	Is new tank to sit on a pad or the ground ?	See line #7.
Line #11	assume contractor responsible for equipment to lift and place the tank ?	Correct. Please see IFQ Section 1
Line #12	Contract docs call for exterior sand blasting and painting . Is interior not required?	Industry Standard and IFQ Section 3
Line #13	Is any bonding required ?	See IFQ Form SPC-001
Line #14	Is or will there be fuel in old tanks to transfer to the new tank or dispose of?	Neither. Will be dispensed new by fuel truck
Line #15	Do you know what the available service voltage is at the Galena site?	We do not.
Line #16	Under SECTION 2: Scope of Work: "Install new equipment from pump to nozzle." Does this mean that an existing pump will be utilized, or will a new pump be required?	New pump. This is to be a complete system.