



THE STATE
of **ALASKA**
GOVERNOR MIKE DUNLEAVY

Department of Military and Veterans Affairs

FMO Design and Construction

57024 Roosevelt Rd
PO Box 5169
JBER, AK 99505

Email: mvafmocontracts@alaska.gov Issue Date: 10/23/24

ATTN: Vendors

RE: **Project Name:** **BAAF Bldg.# 47420 Boiler Replacement**
 Project Number: 02A7024020
 Project Location: JBER, Alaska

Addendum # (3)

This addendum forms a part of the contract documents and modifies the original drawings and/or specifications for the subject work. In case of conflicts between this addendum and previously issued documents, this addendum shall take precedence.

Question from Contractor: How much Glycol will be needed?

Answer: We have decided to use Water instead of Glycol.

This addendum is considered part of the Invitation to Bid (ITB) and is to be acknowledge on your proposal.

Please contact me if you have any questions.

Sincerely, scott.stewart@alaska.gov

End of Addendum