

STATE OF ALASKA

Department of Public Safety
Division of Administrative Services



Galena Fuel Tank

IFQ Number: PR25AC0702A
Amendment#3

November 1, 2024

This amendment is being issued to *provide clarification for electrical requirements.*

Important Note to Offerors: You must sign and return this page of the amendment document with your proposal. Failure to do so may result in the rejection of your proposal. Only the RFP terms and conditions referenced in this amendment are being changed. All other terms and conditions of the RFP remain the same.

Olivia Jewell
Facilities Manager 1
Phone: (907) 269-5647
Email: Olivia.jewell@alaska.gov

COMPANY SUBMITTING PROPOSAL

AUTHORIZED SIGNATURE

DATE

Questions submitted by potential offerors and answers from the state:

Question: "Section 2 - SOW makes no reference to excavating or running power from existing trooper housing or connecting to the tank. Will the electrical need to have a plug so that the tank can be mobile, or will it be stationary with underground permanent conduit power supply to one location?"

Answer: The pump shall be wired to a standard three wire plug. The pump will be powered by a generator as needed for pump the fuel out. This would work with the 75' arctic hose