

KRAKBERGER DRILLING, INC.  
PUMP TEST DATA SHEET

PROJECT: KENAI TEST WELL 2A DATE OF TEST: 5/29/2014

WELL LOCATION(Legal descrpt) BEAVER LOOP

WELL DEPTH- 208 CASING: 206 SCREEN: .010 203-208

DATE WELL COMPLETED: 6/8/2010 DRILLER: RRK

STATIC LEVEL(top of casing) 39' 1"

Clock Time	Elapsed time since Pumping Started/ Stopped, Min.	Depth To Water Ft-In	Recovery Rate GPM	Remarks
10:30		39' 1"	75	water meter
10:32		64' 4"	75	start
10:35		64' 2"	75	7158025
10:35		64' 2"	75	stop
10:40		64' 3"	75	7198700
10:45		64' 4"	75	
10:50		64' 3"	75	
10:55		64' 3"	75	
11:00		64' 3"	75	
11:10		64' 3"	75	
11:22		64' 3"	75	
11:30		64' 3"	75	
11:35		86' 7"	150	
11:42		87' 4"	150	
11:45		87' 7"	150	
11:50		87' 8"	150	
11:55		87' 9"	150	
12:00		87' 10"	150	
12:13		88' 2"	150	
12:20		88' 2"	150	
12:30		88' 5"	150	
12:35		122' 8"	225	
12:38		124' 7"	225	
12:45		124' 10"	225	
12:50		125' 3"	225	
12:55		125' 10"	225	
13:00		125' 10"	225	
13:10		126' 1"	225	
13:20		126' 3"	225	
13:30		126' 4"	225	
13:35		147' 1"	273	
13:40		148' 2"	273	
13:45		149'	273	
13:50		150' 6"	273	
13:55		151' 7"	273	

14:03		151' 10"		273	
14:10		152' 1"		273	
14:20		152' 5"		273	
14:30		152' 8"		273	
	RECOVERY				
	0	t/t'			t/t'
14:35	64' 1"				
14:40	47' 8"				
14:45	46' 6"				
14:50	45' 9"				
14:55	45' 3"				
15:00	44' 8"				
15:05	44' 5"				
15:15	44' 3"				
15:25	43' 6"				
15:35	42' 2"				
15:47	43' 6"				
16:05	36' 6"				
16:22	37' 5"				
16:53	38' 1"				

# CITY OF KENAI WELL 2D DRAWDOWN TEST (MAY 29 2014)

