

**RFQ # 25MUL0113A**

**Amendment # 1**

**Issued: January 17, 2025**

This amendment serves to provide answers to questions received. All other terms and conditions of RFQ # 25MUL0113A shall remain the same. Bidders must sign and return this amendment with their quote, or they may be considered non-responsive.

**Question 1:** Is there a load bank on site for load bank testing or a generator mounted load bank?

**Answer 1:** There is no load testing bank on site. Contractor must provide them. Each generator is 350Kw. Simulated power outage for annual no load bank needed.

**Question 2:** Can the quarterly building load tests be performed in place of the quarterly building load banks?

**Answer 2:** Not able to use building load test for quarterly load banks. Generator are load tested individually one each quarter and then the annual for all three.

**Question 3:** Would we be able to get the serial numbers of each generator?

**Answer 3:** Generator serial numbers: MM-3026125-1, MM-3026125-2, NJ-3081452

---

Vendor Name

---

Signature of Authorized Representative

---

Date