



**State of Alaska**  
**Department of Environmental Conservation**  
**Village Safe Water Program**

555 Cordova Street  
Anchorage, AK 99501  
[april.akers@alaska.gov](mailto:april.akers@alaska.gov)

March 10, 2025

To: Vendor List

Re: Amendment 1  
ITB 25-VSW-PTU-021  
Platinum Exploratory Water Supply Well  
ITB Due Date: March 14, 2025 @ 2:00 PM AST

**The following are vendor questions and the department's response:**

1. Vendor: Do you have a village contact for housing and fuel?

Department: Yes. Interested vendors may contract Mark Moyle, [moylemc@gmail.com](mailto:moylemc@gmail.com) or phone number 907-979-2010.

2. Vendor: Due to the difficulty of obtaining NSF casing, is our standard locally purchased casing approved?

Department: Yes, standard locally purchased well casing is acceptable.

3. Vendor: Is there a misprint on the 100 and 200 slot screen? Should it be 10 and 20?

Department: Yes, there Was a typo, and the well screen sizing should be 10 and 20 slot.

4. Vendor: Yes, the mats we have are Alturna ground protection HDPE 4x8 mats are they approved?

Department: Yes, the Alturna ground protection HDPE 4x8 mats are acceptable for use as the tundra mats.

April Akers

*April Akers*

Procurement Specialist