

**INVITATION TO BID**  
**25-N0817C**  
**Alaska Veterans & Pioneers Home – Roof Replacement**

**Issued: APRIL 4, 2025**

**ADDENDUM NO. 4**

Information in this addendum takes precedence over original information. All other provisions of the document remain unchanged.

**Note to Bidders:** Bidders are required to acknowledge this addendum on the bid form.

This addendum consists of:

1. Addendum No 4-document consisting of 1 page
2. Contractor Question
3. Attachments:
  - Addendum No. 4
4. Bid Deadline remains **April 8, 2025 @ 2:00 PM**

**Contractor Question**

1. **Question:** Specification 07 41 13 s2.2-B.2.b calls for a 3-coat fluoropolymer finish. Manufacturers are having trouble meeting the warranty periods for the 3-coat. Is a 2-coat acceptable.  
**Response:** 2-coat fluoropolymer finish acceptable.

**ATTACHMENTS:**

1. **25-N0817C Addendum #4.pdf**

END OF ADDENDUM 4

Issued: 4/4/2025