



THE STATE
of **ALASKA**
GOVERNOR MIKE DUNLEAVY

Department of Corrections
DIVISION OF ADMINISTRATIVE SERVICES

802 3rd Street, Suite 220
Douglas, Alaska 99824
Tel: 907-465-8169
Email: erin.messing@alaska.gov

June 27, 2025

ATTN: Vendors

RE: **Project Name:** YKCC Sewer Line Repairs
 Project Number: 250002682-1
 Project Location: Yukon Kuskokwim Correctional Center, Bethel, Alaska
 ITB Deadline **July 1, 2025 @ 2:00 P.M. local time**

Addendum# Three (3)

The Department of Corrections is issuing this Addendum to the Invitation to Bid (ITB) for the above referenced project.

The following are questions from interested parties and the department's response:

Q: Trench Detail 2/C200 Note 1. Will the state be providing classified material for backfill around the building?

A: *No.*

Q: Does contractor need to supply compaction testing?

A: *No.*

Q: Detail 1/C200. The term electrical heat trace conduit is referring to heat trace channel and does not require heat trace to be run in emt conduit?

A: *Correct.*

Q: Are redlines on construction drawings acceptable for clean record drawings?


A: *Yes.*

Q: For our bid bond, can it be submitted electronically or do you need a hard copy sent over?

A: *For the bid bond, an electronic copy is acceptable.*

This addendum is considered part of the Invitation to Bid (ITB) and is to be acknowledged on your quote form.

Sincerely,

A handwritten signature in blue ink, appearing to read 'Erin Messing', with a stylized flourish at the end.

Erin Messing
Procurement Specialist IV

cc:

John Gard, DOC Facilities Manager

Michael Lim, DOC Procurement Specialist V

End of Addendum