

Wheaton Water Wells, Inc.

P. O. Box 871218 Wasilla, AK 99687 (907) 376-2041

Well Flow Test

Project Talkeetna Lodge

Date of Test 7/2/98

Well # 1

Well Site T26N, R4W, SEC 30-31

Casing 6"

Well Depth 242'

Screen 5' (80 slot) & 5" (100 slot)

Date Drilled 7/1/98

Static Water Level 144

Driller Wheaton Water Wells

Date Level Taken 7/1/98

Clock Time	Elapsed Time In Minutes	Depth to Water	G. P. M.	Remarks
11:00	0	144	0	start light brown water water is clear
11:01	1	148	115	
11:05	5	149	115	
11:10	10	149	115	
11:15	15	149	115	
11:20	20	149	115	
11:25	25	149	115	
11:30	30	149	115	
11:35	35	149	115	
11:40	40	150	115	
11:45	45	150	115	
11:50	50	150	115	
11:55	55	150	115	
12:00	60	150	115	
12:30	90	150	115	
1:00	120	150	115	
1:30	150	150	115	
2:00	180	150	115	
2:30	210	150	115	
3:00	240	150	115	

Clock Time	E. T. M.	Recovery	G. P. M.	Remarks
3:00	0	150	0	pump off
3:05	5	144		

N 502.18 97.5
W 300.05 102.0

Wheaton Water Wells, Inc.

P. O. Box 871218 Wasilla, Alaska 99687
(907) 376-2041

Well Log

Well Site #1
Talkeetna Lodge

Lot -- **Block** --

Billed To

Howdie Investments
4401 Palmer-Wasilla Hwy
Wasilla, AK 99654

Well Depth
242

Gals/Min
115

Static Level
144

Casing Size
6"

Liner Pipe
no

Screened
5' (80 slot) & 5' (100 slot)

Perforated
no

Date Drilled 7/1/98

From To Formation

0	3	fill
3	30	dirty hardpan
30	40	silt, hardpan
40	50	brown hardpan
50	62	silt, hardpan
62	98	brown hardpan
98	120	sand
120	140	hardpan
140	160	damp sand
160	190	hardpan
190	220	tight gravel, sand, water
220	242	loose gravel, sand, water

Driller Jason Tichenor

COPY