

Wheaton Water Wells, Inc.

P. O. Box 871218 Wasilla, AK 99687 (907) 376-2041

Well Flow Test

Project	Talkeetna Lodge	Date of Test	6/29/98
WELL #2			
Well Site	T26N, R4W, SEC 30-31	Casing	6"
Well Depth	222'	Screen	10' (80 slot)
Date Drilled	6/26/98	Static Water Level	143
Driller	Wheaton Water Wells	Date Level Taken	6/26/98

Clock Time	Elapsed Time in Minutes	Depth to Water	G. P. M.	Remarks
1:00	0	143	0	Start
1:01	1	147	110	slight grey color
1:05	5	149	110	
1:10	10	149	115	open throttle valve
1:15	15	149	115	
1:20	20	150	115	
1:25	25	150	115	water is clear
1:30	30	150	115	
2:00	60	150	115	
2:30	90	150	115	
3:00	120	150	115	
3:30	150	150	115	
4:00	180	150	115	
4:30	210	150	115	
5:00	240	150	115	

Clock Time	E. T. M.	Recovery	G. P. M.	Remarks
5:00	0	150	0	pump off
5:05	5	143		

Wheaton Water Wells, Inc.

P. O. Box 871218 Wasilla, Alaska 99687
(907) 376-2041

Well Log

Well Site

Lot Talkeetna Lodge **Block** #2

Billed To

Howdie Investments
4401 E. Palmer-Wasilla Hwy.
Wasilla AK 99654

Well Depth

222'

Gals/Min

Pump test 115

Static Level

143'

Casing Size

6"

Liner Pipe

No

Screened

10' (80 slot)

Perforated

No

Date Drilled 6/26/98

From	To	Formation
------	----	-----------

0	3	Fill
3	30	Dirty Hardpan
30	40	Silty Hardpan
40	50	Brown Hardpan
50	62	Silty Hardpan
62	98	Brown Hardpan
98	120	Sand
120	140	Hardpan
140	160	Damp Sand
160	190	Hardpan
190	210	Tight Gravel/Sand/H2O
210	222	Loose Gravel/Sand/H2O

Driller

Jason Tichenor