

STATE OF ALASKA

Department of Public Safety
Division of Administrative Services



Fairbanks Post Impound Lot & Fencing

ITB # 26MUL080C

Amendment # 1

September 16, 2025

This amendment is being issued to clarify scope of work.

Important Note to Offerors: You must sign and return this page of the amendment document with your bid. Failure to do so may result in the rejection of your bid. Only the ITB terms and conditions referenced in this amendment are being changed. All other terms and conditions of the ITB remain the same.

Olivia Jewell
Facilities Manager
Phone: (907) 269-5647
Email: Olivia.jewell@alaska.gov

COMPANY SUBMITTING BID

AUTHORIZED SIGNATURE

DATE

Vendor Questions:

Question 1: The specs appear to require bottom rail, but the drawings show bottom tension wire. Which is correct.

Answer: Tension wire shall be installed on the bottom of the fencing fabric.

Question 2: The existing fence that we are supposed to be tying into, is privacy fence. Is the rest of the fence, or any portion, supposed to be privacy fence to match?

Answer: Privacy slats are not required in impound yard fencing or connection to existing fencing.

Question 3: Fence assembly specs call for 2-3/8" line posts 10'o.c. and 2-7/8" terminal posts. Please verify that this is the proper sizing for a 10' tall fence.

Answer: Line posts shall be 2-7/8" and terminal posts shall be 4".

Question 4: Detail 3/c701 calls for a 6" layer of "aggregate" surface. Please specify size and type of aggregate required. i.e. D-1, RAP, or.....

Answer: Aggregate Surface Course is defined in Specification section 31 20 00 2.1 E.

Question 5: Please verify that survey has already been, or will be completed prior to contract award

Answer: Survey data is provided on drawing sheet C100 "Survey Notes".
