



Issue Date: September 17th, 2025

ATTN: Vendors

RE: **Project Name:** Bryant Army Airfield (BAAF) 47428 Remodel Project
 Project Number: 02A7025006
 Project Location: BAAF Building 47428, JBER, AK 99505

Addendum # Three
(3)

This addendum forms a part of the contract documents and modifies the original drawings and/or specifications for the subject work. In case of conflicts between this addendum and previously issued documents, this addendum shall take precedence.

The following question has been received, answered, and changes below are required:

1. Question: Is there 3-phase power available? What is the voltage and amperage? 60 amp 3-phase may be needed for the flooring equipment.

Answer: I talked to our Maintenance Department, and they said, "There is 120/208 3 phase in the building. There is also room in the panel to temp in the equipment. The contractor will need a 208v 3 pole 60a Square D bolt on breaker."

Please contact me if you have any questions.

Sincerely,

Scott Higbee, BMS

907-428-7175

End of Addendum

Offerors must sign and return this addendum in their proposal package. The signature section is on the next page.

A bid submitted without this signed and dated addendum will be considered non-responsive and the offer rejected.

OFFEROR: _____

PHYSICAL ADDRESS: _____

CITY: _____ STATE: _____ ZIP: _____

CONTACT PERSON: _____

BUSINESS PHONE: _____

EMAIL ADDRESS: _____

SUBMITTED BY: _____

DATE: _____

AUTHORIZED REPRESENTATIVE'S PRINTED NAME AND SIGNATURE