

**STATE OF ALASKA ITB NUMBER 2526S023  
AMENDMENT NUMBER ONE**

***AMENDMENT ISSUING OFFICE:***



Department of Transportation & Public Facilities  
Statewide Contracting & Procurement  
P.O. Box 112500  
(3132 Channel Drive, Room 350)  
Juneau, Alaska 99811-2500

**THIS IS NOT AN ORDER**

**DATE AMENDMENT ISSUED: 7 October 2025**

**ITB TITLE:**  
**Sheldon Jackson Museum HVAC Upgrades**

**This is an informational amendment and is not a mandatory return amendment.**

**The purpose of this amendment is to:**

- Answer two questions clarifying product compatibility.

**QUESTION:**

Page 8 of the project manual lists Trane equipment and the schedule is Samsung. Which is the preferred basis of design for this project?

**ANSWER:**

Samsung was the original Basis of Design. Mitsubishi was determined as an available substitute. It is the state's view that the two systems are equivalent.

**QUESTION:**

The Samsung equipment on the schedule is no longer available with 410a. Is equipment with a different refrigerant acceptable?

**ANSWER:**

The intent is to supply R410A equipment, a different refrigerant is not acceptable. An equivalent system by a different manufacturer, of equal quality, is allowed. All performance, electrical requirements, equipment options, etc. must match the Basis of Design System.

Signed by:  Date 10/7/2025  
Signature 0EE5FA1D9E024FD...

Name: Erik Shook / Procurement Specialist