

**STATE OF ALASKA ITB NUMBER 2526C003  
AMENDMENT NUMBER ONE (1)**



Department of Transportation & Public Facilities  
Division of Supply & Services  
2200 E. 42<sup>nd</sup> Avenue  
Anchorage, AK 99508

**THIS IS NOT AN ORDER**

**DATE AMENDMENT ISSUED: 10/27/2025**

**ITB TITLE: OFFICE TRAILER – MATERIALS LAB**

**INFORMATIONAL AMENDMENT**

**THIS AMENDMENT SERVES TO:**

1. Answer questions from a vendor. A vendor asked the following questions:

**Q1:** *The Exterior Wall Framing finish schedule calls for "1/4" Type X EcoSmart Vinyl Covered Polyester - VCP"..Did the design by chance mean Vinyl Covered Gypsum? Would this be an allowable substitute? We have used this in previous modular builds and seems to be more available than VCP.*

**A1:** **The Vinyl Covered Gypsum looks inline with the trailers we have currently and appears to be a reasonable product for the use we need.**


**Q2:** *The structural floor framing finish schedule calls for "Single Layer 3/4" Pressed Bamboo", would 3/4" CDX be allowed as a cost effective substitute.*

**A2:** **This substitution is also well within the range of what would work for our needs, as this subfloor, and 3/4" CDX is a common building material for that application.**

2. Extend the bid opening date:

ORIGINAL ITB OPENING DATE & TIME: **10/28/2025 @ 2:00 PM ALASKA TIME**

NEW ITB OPENING DATE & TIME: **11/04/2025 @ 2:00 PM ALASKA TIME**

\_\_\_\_\_  
  
\_\_\_\_\_  
10/27/2025

\_\_\_\_\_  
**Ben Wright**  
**Procurement Officer**

**SIGNATURE**

**DATE**