



November 4, 2025

ATTN: Vendors

RE: **Project Name:** STWD Doors – ACC Rec Yard Doors
 Project Number: 240000077-2
 Project Location: Anchorage Correctional Complex, Anchorage, Alaska
 ITB Deadline: **November 10, 2025 @ 2:00 P.M. local time**

Addendum# Two (2)

The Department of Corrections is issuing this Addendum to the Invitation to Bid (ITB) for the above referenced project.

The following additions/changes are required:

1. On Addendum One (1), the answer to Question 5 needs to be corrected. Below is the question and corrected answer:

Question 5: Section 02 41 19, Part 3, requires patching and painting of holes after removing the temporary secure barrier, but it does not define the extent of repainting. Please confirm whether only localized touch-up painting of the patched holes is required.

Corrected Answer: Re-painting patched finish surfaces will be required. Only localized touch-up painting of the patched holes is required.

The following are questions from interested parties and the department's response:

Question 1: It was mentioned on-site that Maintenance runs heavy equipment through those doors for maintenance operations. Can you please advise what is the MINIMUM required clear opening of the finished door installation after the new doors and/or frames are installed?

Answer: Minimum required clear opening to be 7' 8".

This addendum is considered part of the Invitation to Bid (ITB) and is to be acknowledged on your quote form.

Sincerely,

A handwritten signature in blue ink, appearing to read "Erin Messing".

Erin Messing
Procurement Specialist IV

cc:
Shawn Ratliff, DOC Facilities Manager
Michael Lim, DOC Procurement Specialist V

End of Addendum