

**STATE OF ALASKA ITB NUMBER 2526H037
AMENDMENT NUMBER ONE (1)**

AMENDMENT ISSUING OFFICE:



Department of Transportation & Public Facilities
Statewide Contracting & Procurement
2301 Peger Road
Fairbanks, AK 99709

THIS IS NOT AN ORDER

DATE AMENDMENT ISSUED: December 10, 2025

ITB TITLE: Northern Region Bridge Timbers

DUE DATE: December 30, 2025 at 11:00 AM. (Alaska Time)

This is a mandatory return Amendment. *Your bid may be considered non-responsive if this signed amendment is not received [in addition to your bid] by the date and time bids are due.*

Vendor Signature: _____

Date: _____

Printed Name: _____

Offerors Name: _____

The purpose of this Amendment #1 is to:

- **Remove "Treated Timber Specifications" from SEC. 2.01 SCOPE OF WORK in its entirety and replace with the following.**

Treated Timber Specifications:

- *Timbers shall be Douglas Fir #2 or better*
 - *Ends shall be square cut.*
 - *Dimensions are specified in Lot four (4) of the Bid Schedule.*
 - *The delivered unit (s) shall be fully weather wrapped.*
 - *Dunnage material shall be wood, minimum of 3.5" high, banded to the bottom of unit to aid in handling.*
 - *Treated Timbers. Surfacing: S4S. Use preservatives and treatment processes found in AWPA UC4B.*
 - *Lumber. Surfacing: S4S. Treat all lumber in accordance with AWPA UC4B.*
- **Provide answers to questions received.**

This is a mandatory return amendment.

Questions and answers

Question #1:

22% Moisture Content is listed, but that's not an option. We can get either KD at 19% or less, or green at whatever %. Please advise.

Answer #1:

In **Sec. 2.01 Scope of Work** it states “**No more** than 22% moisture content”. 19% or less is acceptable.

Question #2:

Regarding the “*nominal size 3” x 12” x 16”*”- If it’s KD, the size requested is not “nominal”. For a KD 3x12 nominal size would be 2.5” x 11.25”. If the size requested needs to be KD, we’d have to start with 4x14. If you can use green (which would make the most sense) we can get it run to the dimensions requested with a slight upsize (3-1/4 x 12-1/4) as our starting point and surface it back to 2.75 x 11.75. Or we can do 3x12 green surfaced to 2.5 x 11.5. Please advise what you’d like us to quote.

Answer #2:

The untreated timbers must be a minimum of 2.75”x11.75” x length specified. S1S2E finished.

Question #3:

Treated Timber Specifications

S1S2E is listed in one spot and then S4s in another. Please clarify which is required. Either way, please advise if the finished dimensions of 1/2” off full is acceptable. (i.e., 6x8 surfaced to 5.5” x 7.5”)

Answer #3:

S1S2E has been removed from the treated timbers specifications as noted above. Yes, 1/2” off full is acceptable. For Example, a 6x6x8 may measure 5 1/2” x 5 1/2” x 8’.

Question #4:

Regarding “Treated Timbers: Surfacing: S4S. *Use preservatives and treatment processes found in AWWA UC4B*”. Please note that AWWA UC4B does not list out a specific treatment. Please advise which specific treatment type is required (example: ACQ, ACZA, CuN-W, CA, etc.)

Answer #4:

Treatment UC4B / ACQ. TYPE B or C.

Question #5:

Please confirm that the 3 different piece counts listed for “Untreated Timbers” is the 3x12 decking and that there’s a total of 1,410 pcs of 3x12-16’ needed.

Answer #5:

The totals required for the untreated timbers are specific for each location and specified in the bid schedule.

Question #6:

On the treated timbers there’s not a moisture content listed, please confirm these are green.

Answer #6:

The moisture content must fall within acceptable limits to ensure proper treatment can be performed.

Signature:  Signed by: **Adam Tolles** Date: 12/10/2025
C72D068D8A7C4C1...

Name: Adam Tolles
Title: Procurement Specialist