

Addendum

DEPARTMENT OF TRANSPORTATION & PUBLIC FACILITIES
SOUTHCOAST REGION CONTRACTS SECTION
6860 GLACIER HIGHWAY
JUNEAU, ALASKA 99801-7999
TELEPHONE: (907) 465-4488
FAX: (907) 465-4238

TO ALL PROSPECTIVE BIDDERS AND OTHERS INTERESTED IN PROJECT NO.
Project No. SPC25263015/SFHWHY00687
Project Name: KTN Lewis Reef Road Tunnel Lighting & Fire Suppression System

ADDENDUM NO. 2

January 14, 2026

This transmittal consists of ONE (1) page including this cover sheet. **If any pages are missing or clarification is needed, contact the Southcoast Regional Contracts Office immediately.**

The Plans are modified as follows:

Add the following to note C on Sheet U1:

THE FOLLOWING REPLACEMENT LIGHT FIXTURE EXAMPLES, OR AN ENGINEER-APPROVED EQUAL, ARE CONSIDERED IN-KIND AND ARE ACCEPTABLE:

- APPLETON EMERSON MERCMMASTER IMLG-C-X1-2-N-P-W-BH
- COOPER MCGRAW-EDISON TOP-TIER TT-D10-740-8-WQ-SURFACEMOUNT-30L-CEC-6FT PIGTAIL
- HOLOPHANE TNLED2-PK1-40K-HVOLT-CLN-DGRA-SCRW
- PARAMOUNT PMG2-2-SURFACE-480V-4K-70L-CIR83-S3-L7

PROVIDE AND INSTALL ALL NECESSARY COMPONENTS THAT ARE NOT INCLUDED WITH THE REPLACEMENT FIXTURES IN ORDER TO MOUNT EACH FIXTURE PER MANUFACTURER'S INSTRUCTIONS AND RECOMMENDATIONS.

Bidders should acknowledge this addendum on the proposal form or by FAX prior to the bid opening.

Addendum Number TWO (2) received.

Project No. SPC25263015/SFHWHY00687
Project Name: KTN Lewis Reef Road Tunnel Lighting & Fire Suppression System

Name/Title

Date

Firm