



April 3, 2026

ATTN: Vendors

RE: **Project Name:** STWD Backup Power – FCC Generator
 Project Number: 230000534-8
 Project Location: Fairbanks Correctional Center, Fairbanks, Alaska
 ITB Deadline: **April 10, 2026 @ 2:00 P.M. local time**

Addendum Two (2)

The Department of Corrections is issuing this Addendum to the Invitation to Bid (ITB) for the above referenced project.

The following are questions from interested parties and the department's response:

Question 1: Sheet note #2 E-601 reads as follows "EXTEND EXISTING CONDUITS TO GENERATOR MODULE. PROVIDE NEW FEEDER TO ATS 'EDP'." and directly indicated by sheet note #2 flag is the text "(3 SETS) 3"C, (4) 250KCMIL W/ #2/0 GND". The existing installation utilizes (2) 3-1/2" conduits, not (3) 3" conduits. Will you please evaluate if (2) 3-1/2" conduits will be sufficient for the new generator, and if so, provide a new feeder schedule appropriately modified?

Answer: For (2) 3-1/2 conduits the feeder shall be (2 SETS) (4) 350KCMIL W/ #2/0 GND.

Question 2: Has a hazardous material survey been performed where new piping/conduit travel through existing walls?

Answer: No.

Question 3: Are new piping/conduit required to be painted in occupied areas?

Answer: Yes.

Question 4: Is Contractor required to hire a registered engineer in the State of Alaska to design and inspect concrete forms? Reference 03 10 00 1.5 and 3.7.

Answer: Yes, the Contractor is to hire a structural engineer for design of the concrete forms and inspection.

This addendum is considered part of the Invitation to Bid (ITB) and is to be acknowledged on your quote form.

Sincerely,


Erin Messing
Procurement Specialist IV

cc:
Shawn Ratliff, DOC Facilities Manager
Michael Lim, DOC Procurement Manager

End of Addendum