

Z

STATE OF ALASKA INVITATION TO BID (ITB) AMENDMENT NO. 2



ITB 2026-1000-0268 HAZARDOUS MATERIALS STORAGE UNITS

ITB 2026-1000-0268
ISSUED 4/6/26

THIS ADDENDUM HAS BEEN ISSUED TO ANSWER QUESTIONS FROM VENDORS AND EXTEND THE DEADLINE FOR BIDS.

IMPORTANT NOTE TO BIDDERS:

Bidders are required to sign and return this addendum page with their bid. Failure to do so may result in rejection of the bid. This addendum modifies only the ITB terms and conditions specifically identified herein. All other terms and conditions of the ITB remain unchanged. This addendum is incorporated into and made part of the ITB and consists of **two (2) pages**.

CONTRACTING OFFICER

Madelyn F. Lowe

Fire Protection Program

(907) 761 – 6351

madelyn.lowe@alaska.gov

Company Name:

Alaska Business License No.:

Phone Number:

Email Address:

Authorized Representative Name:

Authorized Representative Signature:

Date Amendment Signed:

Questions submitted by potential offerors and answers from the state:

Question 1: Will any of these buildings need to be fire rated? If so, which fire rating is needed? 2 hour fire rating or 4 hour fire rating?

Answer: No, a fire rating is not required.

Question 2: Will swing doors with hold open devices be accepted instead of roll up doors or sliding doors?

Answer: Line item 1, Walk-In Storage Unit, may have a hinged door. Line item 2 and 3 must have roll-up or sliding doors.

Question 3: Is State approval required for each of these buildings or will a PE Stamp work?

Answer: A PE stamp is sufficient. Coordination with AHJ is the responsibility of the state.

Question 4: Sections 2.15 (New Equipment) and 2.16 (Remanufactured/Reconditioned Equipment) appear to conflict. Section 2.15 states that the State will not accept remanufactured or reconditioned equipment, while Section 2.16 indicates that remanufactured/reconditioned equipment may be acceptable if certain requirements are met. Can the State clarify whether remanufactured or reconditioned equipment will be accepted under this ITB?

Answer: Remanufactured or reconditioned equipment will **not** be accepted under this ITB. Equipment provided must be new in accordance with SEC. 2.15. SEC. 2.16 does not apply to this solicitation.

Question 5: Additionally, can the State provide the ship-to addresses for each container/location referenced in this solicitation?

Answer: The FOB point for delivery is:
210 Alta Way, Fairbanks, Alaska 99709

Changes to the RFP:

Change 1: The deadline for bids has been extended. The new deadline for bids is 4/13/2026 at 2:00 PM Alaska Standard Time.

End of Amendment No. 1