

STATE OF ALASKA

Department of Military & Veterans Affairs
Division of Administrative Services



REQUEST FOR QUOTES (RFQ) 260000015 H21 400Hz GPU

ADDENDUM 1

ISSUED MAY 21, 2026

This addendum is being issued to answer questions from vendors.

Important Note to Offerors: You are required to sign and return this page of the addendum document with your quote. Failure to do so may result in the rejection of your quote. Only the RFQ terms and conditions referenced in this addendum are being changed. All other terms and conditions of the RFQ remain the same.

JANNAH ALAGANO

Procurement Specialist 3

Phone: 1 (907) 428-7222

Email: Jannah.alagano@alaska.gov

COMPANY SUBMITTING QUOTE

AUTHORIZED SIGNATURE

DATE

QUESTIONS SUBMITTED BY OFFERORS AND ANSWER FROM THE STATE

Question 1: *What is the requested/required lead time for delivery of the equipment for this project?*

Answer 1: 60 days after issuance of the contract award (Purchase Order).

Question 2: *Also, the following statement is made in the RFQ, but the specified manufacturer ITW is not compliant as their equipment is manufactured in Denmark and not in the USA. The FCX product is proudly manufactured in Morgantown WV USA.*

Vendor must ensure products complies with the “Build America Buy America” Act (BABA)

400Hz GPU requirements must be equivalent to the following:

- *ITW GSE Model 2400 Solid State Frequency Converter, existing unit shown in Figure 1 and Figure 2*
- *Type: 3GWF-200/260-N*
- *Part No.: 578.650*
- *Input: 3 x 460 V +/- 15%, 3 x 123 A +/- 15%, 3W+PE, 50/60Hz*
- *Output: 200 V, 260 A, 90 kVA, PF1, 3W+N, 400Hz*
- *Number of outputs: 2. Each rated: 90 kVA*
- *Weight: approx. 683lbs*
- *Fixed, upright unit*

Answer 2: The listed model is for reference only and that State-approved equivalents will be accepted if they meet or exceed the essential performance requirement.

END OF ADDENDUM 1