



Issued Date: May 27, 2026

ATTN: Vendors

RE: Project Name: YKCC STWD Backup Power Generator
Project Number: 230000534-9
Project Location: Yukon Kuskokwim Correctional Center (YKCC), Bethel, Alaska
ITB Deadline: **May 29, 2026 @ 2:00 p.m. local time**

Addendum # One (1)

This addendum forms a part of the contract documents and modifies the original drawings and/or specifications for the subject work. In case of conflicts between this addendum and previously issued documents, this addendum shall take precedence.

The following are questions from interested parties and the department's response:

Q: After the existing generator and battery(s) are removed, whom takes possession of it and/or where shall it be delivered?

Response: The generator and battery(s) are to be demolished and removed from the premises. Disposal is the responsibility of the contractor.

Q: Could the existing MDP box remain as a pull or splice box for the branch feeder if all interior components are removed and a blank cover provided?

Response: Yes

This addendum is considered part of the Invitation to Bid (ITB) and is to be acknowledged on your quote.

Please contact me if you have any questions.

Sincerely,

Michael Lim

Michael Lim
Procurement Manager

cc: John Gard, Facilities Manager I, DOC

End of Addendum