



State of Alaska
Department of Environmental Conservation
Village Safe Water Program

555 Cordova Street
Anchorage, AK 99501
John.mcdonald@alaska.gov

August 7, 2026

To: Vendor List

Re: Amendment 6
ITB 27-VSW-KMO-003
Manokotak Backup Generators Replacement
ITB Due Date: August 7, 2026 @ 2:00 PM AST

The following are vendor questions and the department's response:

1. Vendor: In Question #1 in Addendum #2, clarification on whether UL2200 was mandatory and whether generators not UL2200 listed is acceptable. The response isn't clear.

The Department responded by citing Specification Section 2.02 E.3 which states for both generators: "List and label engine generator assembly as complying with UL2200." The department further states that this means the generator must be able to operate at its full rated power output continuously without overheating and must carry a UL2200 compliance label.

Is this Listing requirement no longer required?

The department did not alter/remove/change the specification requirement for listing. Listing and labeling are two different requirements and the specification language requires both.

Are we to assume that the generators only have to be Labeled as complying to the UL2200 standard and be able to operate at its full rated power output continuously without overheating and not also listed for such activity?

Listing requires certification by an approved by an OSHA approved Nationally Recognized Testing Laboratory (NTRL) agency. In which case, they will want to approve the facility to the UL2200 standard as well. As stated in the question, it does add lead time and additional costs

Please verify if the generators do not need to meet the Specification Section 2.02 E.3 specification language to be Listed, but instead only need to be Labeled on the generators as meeting the UL2200 standard.

Department: The generators are not required to be UL2200 listed, but they must comply with all applicable UL2200 requirements.

John McDonald

John McDonald
Procurement Specialist