



Issue Date: August 27, 2026

ATTN: Vendors

RE: **Project Name:** BAAF – 47427 Hangar 6 – Roof and Envelope Replacement
 Project Number: 02A7026001
 Project Location(s): Bryant Airfield, Joint Base Elmendorf-Richardson, Alaska

Addendum # One (1)

This addendum forms a part of the contract documents and modifies the original drawings and/or specifications for the subject work. In case of conflicts between this addendum and previously issued documents, this addendum shall take precedence.

The following administrative changes have been made to this ITB:

1. N/A

Questions and Answers:

1. Reading through the RFP it sounds like we are to re-install the existing light fixtures on the exterior and not provide new, is this correct??
 - A. Contractor will be required to upgrade non-LED fixtures to LED fixtures. New fixtures must match similar existing fixtures. Must be pre-approved by Project Manager.

Please contact me if you have any questions.

Sincerely,

Gavin M. Fairbanks
Building Management Specialist
(907) 428-7187