



State of Alaska
Department of Environmental Conservation
Village Safe Water Program

555 Cordova Street
Anchorage, AK 99501
april.akers@alaska.gov

September 11, 2026

To: Vendor List

Re: Amendment 4
RFP 27-VSW-SLA-001
Slana - First Service to 3 Homes & Dry Well Investigation
RFP Due Date: September 15, 2026 @ 2:00 PM AST

The following are vendor questions and the department's responses:

1. Vendor: The 2016 project included bathrooms, and the 2024 technical memo mentions indoor plumbing, but the RFP does not mention it in Article B2.

Department: Bathrooms are included in the design scope. Add the following language to Article B2 Scope of Service: This work shall include design of:

- Design Element 4: Interior plumbing:
 - Assessment of existing interior plumbing in each home.
 - Design of Interior water distribution piping and drain/waste/vent system needed to provide full indoor service.
 - Bathroom plumbing design (toilet, sink, and shower/tub).
 - Identification of additional plumbing components required to complete full indoor service.

April Akers

April Akers

Procurement Specialist