Alaska Department of Military and Veterans Affairs
Division of Administrative Services

Invitation for Quotes (IFQ) # 09-001-27

AMYA DFAC Flooring Project

Addendum #2

Date of Issue: November 6, 2026

Addendum #2 is being issued to answer questions from interested offerors. This Addendum #2 is hereby made part of the IFQ and is a total of 2 pages.

Issued by:

Jannah Alagano

Procurement Specialist 3

Email: MvaDasProcurement@alaska.gov

Questions submitted by potential offerors and answers from the state:

Question 1: Addendum No. 1 appears to allow flooring types other than seamless resinous systems. Will the State accept commercial-grade, slip-resistant, heat-welded sheet vinyl flooring? Additionally, the substrate will require moisture testing. If moisture levels exceed the flooring manufacturer's acceptable limits, will the State issue a separate solicitation for remediation work?

Answer: The State will accept commercial-grade, slip-resistant, heat-welded sheet vinyl flooring as an approved alternative, provided the proposed product complies with all performance requirements identified in Addendum No. 1 and is installed in accordance with the manufacturer's requirements for the intended application.

Offerors shall include substrate moisture testing as part of their proposal. If moisture testing identifies conditions that exceed the flooring manufacturer's acceptable limits, any required remediation will be evaluated separately by the State based on the findings, scope of work, and available procurement options. The State makes no commitment at this time to issue a separate solicitation for remediation work.

End of Addendum #2