

Notice of Utility Tariff Filing

The REGULATORY COMMISSION OF ALASKA (Commission) gives notice that Chugach Electric Association, Inc. (Chugach) filed a tariff revision designated as TA402-8, proposing an annual update to its generation and transmission (G&T) line loss factor based on operating results for the year ending December 2014. The updated G&T line loss factor is used for the allocation of system costs in calculating the fuel surcharge and revenue requirement, and for determination of losses associated with transmission wheeling transactions. The updated G&T line loss factor is 2.312 percent. By means of comparison, previous line loss factors (measured at generation) were 2.486 percent and 2.875 percent based on 2013 and 2012 operating results, respectively.

Additionally, Chugach has continued to reflect the Bradley Lake Project Management Committee decision for reimbursement of non-Homer Electric Association, Inc. (HEA) Bradley Lake losses through Bradley Lake generation in the G&T line loss calculation. If a decision is made to change how non-HEA Bradley Lake losses are treated, Chugach may update the loss factor calculation prior to its next scheduled update in 2016. Further Chugach has not made any normalization adjustments as a result of the expiration of the Interim Power Sales Agreement between Chugach and Matanuska Electric Association, Inc. (MEA), or adjustments reflecting potential impacts associated with the commercial operation of MEA's Eklutna Generation Station (EGS). The parties have agreed to review the preliminary loss factor results based on calculations through July 2015, in a meeting set for August 13, 2015, to monitor the impact of MEA's incorporation of its EGS.

This notice may not contain all requested revisions and the Commission may approve rates or classifications which vary from that proposed. You may obtain more information about this filing by contacting Arthur Miller, Director, Regulatory Affairs and Pricing at Chugach, at 5601 Electron Drive, P. O. Box 196300, Anchorage, AK 99519-6300; phone: (907) 762-4758. The complete filing is also available for inspection at the Commission's office at 701 West 8th Avenue, Suite 300, Anchorage, AK 99501; phone: (907) 276-6222, or may be viewed at the Commission's website at <http://rca.alaska.gov> by typing Docket "TA402-8" in the *Find a Matter* search box.


To comment on this filing, please file your comments by 5:00 p.m., April 20, 2015, at the Commission's address given above or via our website at:

<https://rca.alaska.gov/RCAWeb/WhatsNew/PublicNoticesComments.aspx>

Please reference TA402-8 and include a statement that you have filed a copy of the comments with Chugach at its address given above or by email at info@chugachelectric.com. Individuals or groups of people with disabilities, who require special accommodations, auxiliary aids or service, or alternative communication formats, please contact Joyce McGowan at (907) 276-6222, toll-free at 1-800-390-2782, TTY (907) 276-4533 or send a request via electronic mail to rca.mail@alaska.gov by April 13, 2015.

DATED at Anchorage, Alaska, this 19th day of March, 2015.

REGULATORY COMMISSION OF ALASKA


James A. Keen
Engineering Section Manager